Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 117

Customer		***Sample Collection***	
Facility Name:	*Hampton Inn*	*Date:*	*11/9/26*
		Time:	10:09 AM
Address:	*1247 Smallman St.*	*Method:*	*Grab*
	Pittsburgh, PA 15222		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*11/12/26*
		Time:	*11:00 AM*
Source Type:	*Spa*	*Analyst:*	*JC*

Accredited Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Escherichia Coli:	Absent	Absent	11/10/26	10:30 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/10/26	10:30 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	11/9/26	4:50 PM	SL	SM 9215B
Additional Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Fecal Streptococcus	0/100mls	2/100mls	11/10/26	10:30 AM	MH	SM 9230C
Field Analysis	**Results**	**Reporting limit**	**Date/Time**		**Analyst**	**Method**
pH:	7.5 SU	7.2 - 7.8 SU	11/9/26	10:09 AM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	11/9/26	10:09 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/9/26	10:09 AM	SL	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)