# Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

*Lab# 234*

***Customer***

*Facility Name:* *North Allegheny High School*

*Address:* *10375 Perry Hwy.*
*Wexford, PA 15090*

*Matrix:* *Recreational Water*

*Source Type:* *Pool Deep*

***Sample Collection***

*Date:* *11/11/26*
*Time:* 9:30 AM
*Method:* *Grab*

***Sample Final Analysis***

*Date:* *11/13/26*
*Time:* *4:30 PM*
*Analyst:* *JC*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 11/11/26 | 4:00 PM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 11/11/26 | 4:00 PM | AS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 11/11/26 | 4:00 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 11/11/26 | 9:30 AM | VH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 11/11/26 | 9:30 AM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 11/11/26 | 9:30 AM | VH | Visual |

**Sample comments**

Andre Smith

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)