Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-1

Lab# 263

Customer

Facility Name: *Residence Inn*

Address: *3455 William Penn Hwy*
Pittsburgh, PA 15235

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *11/10/26*
Time: 10:05 AM
Method: *Grab*

Sample Final Analysis

Date: *11/13/26*
Time: *9:00 AM*
Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/11/26	8:55 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/11/26	8:55 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	11/10/26	3:30 PM	MH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	11/10/26	10:05 AM	SH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	11/10/26	10:05 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/10/26	10:05 AM	SH	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)