Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 362

Customer

Facility Name: *YMCA - Sewickley*

Address: *625 Blackburn Rd.*
Sewickley, PA 15143

Matrix: *Recreational Water*

Source Type: *Deep End*

Sample Collection

Date: *11/10/26*
Time: 3:28 PM
Method: *Grab*

Sample Final Analysis

Date: *11/13/26*
Time: *10:30 AM*
Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/11/26	10:00 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/11/26	10:00 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	11/10/26	6:05 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	11/10/26	3:28 PM	SL	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	11/10/26	3:28 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/10/26	3:28 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor