Lab ID No. 02-04041

# Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

**APM**

***Lab#*** ***2757***

| ***Customer*** | | ***Sample Collection*** | |
|---|---|---|---|
| *Facility Name:* | *Here Apts* | *Date:* | *11/10/26* |
| | | *Time:* | 9:45 AM |
| *Address:* | *3506 Forbes Ave* | *Method:* | *Grab* |
| | *Pittsburgh, PA 15213* | | |
| | | ***Sample Final Analysis*** | |
| *Matrix:* | *Recreational Water* | *Date:* | *11/13/26* |
| | | *Time:* | *10:30 AM* |
| *Source Type:* | *Spa* | *Analyst:* | *JC* |

| **Accredited Analysis** | **Results** | **Reporting limit** | **Incubation Date/Time** | | **Analyst** | **Method** |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 11/11/26 | 10:00 AM | JC | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 11/11/26 | 10:00 AM | JC | SM 9222B |
| Standard plate count: | 5700/ml | 200/ml | 11/10/26 | 6:05 PM | SL | SM 9215B |

| **Additional Analysis** | **Results** | **Reporting limit** | **Incubation Date/Time** | | **Analyst** | **Method** |
|---|---|---|---|---|---|---|
| Fecal Streptococcus | 0/100mls | 2/100mls | 11/11/26 | 10:00 AM | AS | SM 9230C |

| **Field Analysis** | **Results** | **Reporting limit** | **Date/Time** | | **Analyst** | **Method** |
|---|---|---|---|---|---|---|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 11/10/26 | 9:45 AM | JT | DPD |
| Chlorine: | 0.0 mg/l | 1.0 - 5.0 mg/l | 11/10/26 | 9:45 AM | JT | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 11/10/26 | 9:45 AM | JT | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor