



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

W-1

Lab# 020

Laboratory Analysis Report

Customer

Facility Name: *Beaver Area High School*

Address: *Gypsy Glen*
Beaver, PA 15009

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *9/8/26*

Time: *2:15 PM*

Method: *Grab*

Sample Final Analysis

Date: *9/11/26*

Time: *10:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/9/26 10:25 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/9/26 10:25 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/8/26 5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/8/26 2:15 PM	AH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/8/26 2:15 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/8/26 2:15 PM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor