



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**Service**

**Lab# 424**

**Customer**

**Facility Name:** Chatham University  
**Address:** 1 Woodland Rd.  
Pittsburgh, PA 15232

**Matrix:** Recreational Water  
**Source Type:** Pool Deep

**Sample Collection**

**Date:** 9/9/26  
**Time:** 8:20 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 9/12/26  
**Time:** 9:00 AM  
**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 9/10/26              | 8:55 AM | SL      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 9/10/26              | 8:55 AM | SL      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 9/9/26               | 5:00 PM | AS      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.5 SU   | 7.2 - 7.8 SU    | 9/9/26    | 8:20 AM | MB      | DPD    |
| Chlorine:      | 3.2 mg/l | 1.0 - 5.0 mg/l  | 9/9/26    | 8:20 AM | MB      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 9/9/26    | 8:20 AM | MB      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor