



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-3

Lab# 477

Customer

Facility Name: *Comfort Inn Duncansville*

Address: *130 Patchway Rd.
Duncansville, PA 16635*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *9/8/26*

Time: *12:40 PM*

Method: *Grab*

Sample Final Analysis

Date: *9/11/26*

Time: *11:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/9/26	10:55 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/9/26	10:55 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/8/26	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/8/26	12:40 PM	DNP	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	9/8/26	12:40 PM	DNP	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/8/26	12:40 PM	DNP	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)