



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 090

Customer

Facility Name: Doubletree Hotel
Address: Bigelow Square
Pittsburgh, PA 15219

Sample Collection

Date: 9/9/26
Time: 12:45 PM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 9/12/26
Time: 9:00 AM
Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/10/26	8:55 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/10/26	8:55 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/9/26	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/9/26	12:45 PM	EG	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/9/26	12:45 PM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/9/26	12:45 PM	EG	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor