



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 128

Customer

Facility Name: Hampton Inn & Suites North Huntingdon Irwin

Address: 8441 Country Club Drive
North Huntingdon, PA 15642

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 9/8/26

Time: 8:15 AM

Method: Grab

Sample Final Analysis

Date: 9/11/26

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/9/26	9:55 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/9/26	9:55 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/8/26	4:45 PM	MH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	9/8/26	8:15 AM	JC	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/8/26	8:15 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/8/26	8:15 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor