



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**Extra**

**Lab# 2286**

**Customer**

Facility Name: *Ingomar North Swim Club*

Address: *460 Olive Street*  
*Pittsburgh, PA 15237*

Matrix: *Recreational Water*

Source Type: *Shallow End*

**Sample Collection**

Date: *9/9/26*

Time: *12:08 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *9/12/26*

Time: *9:30 AM*

Analyst: *AS*

| Laboratory Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 9/10/26              | 9:25 AM | SL      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 9/10/26              | 9:25 AM | SL      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 9/9/26               | 6:30 PM | AS      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.4 SU   | 7.2 - 7.8 SU    | 9/9/26    | 12:08 PM | SL      | DPD    |
| Chlorine:      | 5.0 mg/l | 1.0 - 5.0 mg/l  | 9/9/26    | 12:08 PM | SL      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 9/9/26    | 12:08 PM | SL      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor