



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 190

Customer

Facility Name: Jewish Community Cntr

Address: 5738 Forbes Ave.
Pittsburgh, PA 15217

Matrix: Recreational Water

Source Type: Women - Spa

Sample Collection

Date: 9/8/26

Time: 1:41 PM

Method: Grab

Sample Final Analysis

Date: 9/11/26

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Escherichia Coli:	Absent	Absent	9/9/26 9:25 AM	JC	SM 9222G
-------------------	--------	--------	----------------	----	----------

Total coliforms:	0/100mls	2/100mls	9/9/26 9:25 AM	JC	SM 9222B
------------------	----------	----------	----------------	----	----------

Standard plate count:	0/ml	200/ml	9/8/26 4:10 PM	MH	SM 9215B
-----------------------	------	--------	----------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Fecal Streptococcus	0/100mls	2/100mls	9/9/26 12:00 PM	JC	SM 9230C
---------------------	----------	----------	-----------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
-----------------------	----------------	------------------------	------------------	----------------	---------------

pH:	7.0 SU	7.2 - 7.8 SU	9/8/26 1:41 PM	JT	DPD
-----	--------	--------------	----------------	----	-----

Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/8/26 1:41 PM	JT	DPD
-----------	----------	----------------	----------------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	9/8/26 1:41 PM	JT	Visual
------------	-------	-----------	----------------	----	--------

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor