



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM

Lab# 2001

Customer

Facility Name: 1400 Main @ Southpointe

Address: 1400 Main St.
Canonsburg, PA 15317

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 9/10/26

Time: 2:13 PM

Method: Grab

Sample Final Analysis

Date: 9/12/26

Time: 5:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/10/26	5:20 PM	SL	SM 9222G

Total coliforms:	0/100mls	2/100mls	9/10/26	5:20 PM	SL	SM 9222B
------------------	----------	----------	---------	---------	----	----------

Standard plate count:	0/ml	200/ml	9/9/26	5:30 PM	SL	SM 9215B
-----------------------	------	--------	--------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
---------------------	---------	-----------------	----------------------	--	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	9/10/26	5:45 PM	SL	SM 9230C
---------------------	----------	----------	---------	---------	----	----------

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
----------------	---------	-----------------	-----------	--	---------	--------

pH:	7.0 SU	7.2 - 7.8 SU	9/10/26	2:13 PM	EG	DPD
-----	--------	--------------	---------	---------	----	-----

Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	9/10/26	2:13 PM	EG	DPD
-----------	----------	----------------	---------	---------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	9/10/26	2:13 PM	EG	Visual
------------	-------	-----------	---------	---------	----	--------

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor