



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

**APM**

Lab ID No. 02-04041

Lab# 2608

**Customer**

Facility Name: Yards @ 3 Crossings

Address: 2645 Railroad St.  
Pittsburgh, PA 15222

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 9/9/26

Time: 10:20 AM

Method: Grab

**Sample Final Analysis**

Date: 9/12/26

Time: 9:30 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method   |
|---------------------|---------|-----------------|----------------------|---------|----------|
| Escherichia Coli:   | Absent  | Absent          | 9/10/26 9:25 AM      | SL      | SM 9222G |

|                  |          |          |                 |    |          |
|------------------|----------|----------|-----------------|----|----------|
| Total coliforms: | 0/100mls | 2/100mls | 9/10/26 9:25 AM | SL | SM 9222B |
|------------------|----------|----------|-----------------|----|----------|

|                       |      |        |                |    |          |
|-----------------------|------|--------|----------------|----|----------|
| Standard plate count: | 0/ml | 200/ml | 9/9/26 6:30 PM | AS | SM 9215B |
|-----------------------|------|--------|----------------|----|----------|

| Additional Analysis | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
|---------------------|----------|-----------------|----------------------|---------|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls        | 9/10/26 10:00 AM     | JC      | SM 9230C |

| Field Analysis | Results  | Reporting limit | Date/Time       | Analyst | Method |
|----------------|----------|-----------------|-----------------|---------|--------|
| pH:            | 7.0 SU   | 7.2 - 7.8 SU    | 9/9/26 10:20 AM | EG      | DPD    |
| Chlorine:      | 5.0 mg/l | 1.0 - 5.0 mg/l  | 9/9/26 10:20 AM | EG      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 9/9/26 10:20 AM | EG      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor