



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 213

Customer

Facility Name: Langley High School

Address: 2940 Sheradan Blvd.
Pittsburgh, PA 15204

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 9/9/26

Time: 1:10 PM

Method: Grab

Sample Final Analysis

Date: 9/12/26

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	9/10/26	8:55 AM	SL	SM 9222G
Total coliforms:	0/100mls	A	9/10/26	8:55 AM	SL	SM 9222B
Standard plate count:	0/ml	A	9/9/26	5:00 PM	AS	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.4 SU	A	9/9/26	1:10 PM	JT	DPD
Chlorine:	7.5 mg/l	E	9/9/26	1:10 PM	JT	DPD
Turbidity:	1 NTU	A	9/9/26	1:10 PM	JT	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)