



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 270

Customer

Facility Name: Science and Technology Academy

Address: 107 Thackeray St.
Pittsburgh, PA 15213

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 9/9/26

Time: 10:57 AM

Method: Grab

Sample Final Analysis

Date: 9/12/26

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	9/10/26	8:55 AM	JC	SM 9222G
Total coliforms:	0/100mls	A	9/10/26	8:55 AM	JC	SM 9222B
Standard plate count:	0/ml	A	9/9/26	5:00 PM	AS	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.4 SU	A	9/9/26	10:57 AM	JT	DPD
Chlorine:	3.0 mg/l	A	9/9/26	10:57 AM	JT	DPD
Turbidity:	1 NTU	A	9/9/26	10:57 AM	JT	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)