# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

**Lab ID No. 02-04041**

**N-3**

***Lab# 450***

[redacted]

***Customer***

*Facility Name:* *Gold Fish*

*Address:* *1115 Freeport Rd.*
*Fox Chapel, PA 15238*

*Matrix:* *Recreational Water*

*Source Type:* *Pool*

***Sample Collection***

*Date:* *4/28/26*
*Time:* 9:08 AM
*Method:* *Grab*

***Sample Final Analysis***

*Date:* *5/1/26*
*Time:* *10:30 AM*
*Analyst:* *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 4/29/26 | 10:10 AM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 4/29/26 | 10:10 AM | AS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 4/28/26 | 5:30 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.8 SU | 7.2 - 7.8 SU | 4/28/26 | 9:08 AM | AMH | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 4/28/26 | 9:08 AM | AMH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 4/28/26 | 9:08 AM | AMH | Visual |

**Sample comments**

Andre Smith

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)