Lab ID No. 02-04041

# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

Andre Smith, Lead Supervisor

**C-2**

***Lab# 446***

| ***Customer*** | | ***Sample Collection*** | |
|---|---|---|---|
| *Facility Name:* | *Comfort Inn* | *Date:* | *3/17/26* |
| | | *Time:* | 12:25 PM |
| *Address:* | *830 East Ohio St.* | *Method:* | *Grab* |
| | *Pittsburgh, PA 15222* | | |
| | | ***Sample Final Analysis*** | |
| *Matrix:* | *Recreational Water* | *Date:* | *3/20/26* |
| | | *Time:* | *10:30 AM* |
| *Source Type:* | *Pool* | *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 3/18/26 | 10:00 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 3/18/26 | 10:00 AM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 3/17/26 | 2:30 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 3/17/26 | 12:25 PM | BH | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 3/17/26 | 12:25 PM | BH | DPD |
| Turbidity: | 2 NTU | 1 - 2 NTU | 3/17/26 | 12:25 PM | BH | Visual |

**Sample comments**

Andre Smith

Andre Smith, Lead Supervisor