Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 177

[redacted]

Customer		***Sample Collection***	
Facility Name:	*Hyatt Place*	*Date:*	*3/16/26*
		Time:	9:06 AM
Address:	*2112 Racetrack*	*Method:*	*Grab*
	Washington,PA 15301		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*3/19/26*
		Time:	*10:30 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Escherichia Coli:	Absent	Absent	3/17/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	3/17/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	3/16/26	4:00 PM	SL	SM 9215B

Field Analysis	**Results**	**Reporting limit**	**Date/Time**		**Analyst**	**Method**
pH:	7.2 SU	7.2 - 7.8 SU	3/16/26	9:06 AM	GR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	3/16/26	9:06 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	3/16/26	9:06 AM	GR	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor