Lab ID No. 02-04041

Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

PPS

Lab# 213

Customer		***Sample Collection***	
Facility Name:	*Langley High School*	*Date:*	*3/18/26*
		Time:	7:52 AM
Address:	*2940 Sheradan Blvd.*	*Method:*	*Grab*
	Pittsburgh, PA 15204		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*3/20/26*
		Time:	*6:00 PM*
Source Type:	*Pool Shallow*	*Analyst:*	*AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	3/18/26	5:26 PM	SL	SM 9222G
Total coliforms:	0/100mls	A	3/18/26	5:26 PM	SL	SM 9222B
Standard plate count:	0/ml	A	3/18/26	5:26 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.4 SU	A	3/18/26	7:52 AM	MM	DPD
Chlorine:	3.0 mg/l	A	3/18/26	7:52 AM	MM	DPD
Turbidity:	1 NTU	A	3/18/26	7:52 AM	MM	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor