Lab ID No. 02-04041

Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

PPS

Lab# 310

Customer

Facility Name: *University Prep Middle School*

Address: *3117 Centre Ave.*
Pittsburgh, PA 15219

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *3/18/26*
Time: 11:16 AM
Method: *Grab*

Sample Final Analysis

Date: *3/20/26*
Time: *6:00 PM*
Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	3/18/26	5:26 PM	SL	SM 9222G
Total coliforms:	0/100mls	A	3/18/26	5:26 PM	SL	SM 9222B
Standard plate count:	0/ml	A	3/18/26	5:26 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	3/18/26	11:16 AM	MM	DPD
Chlorine:	4.0 mg/l	B	3/18/26	11:16 AM	MM	DPD
Turbidity:	1 NTU	A	3/18/26	11:16 AM	MM	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor