



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
W-12

Lab# 2014

Customer

Facility Name: Allegheny C.C.
Address: 250 Country Club Rd
Sewickley, PA 15143

Sample Collection

Date: 8/17/26
Time: 2:35 PM
Method: Grab

Sample Final Analysis

Date: 8/20/26
Time: 10:30 AM
Analyst: AS

Matrix: Recreational Water
Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/18/26	10:25 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/18/26	10:25 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	8/17/26	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/17/26	2:35 PM	EB	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	8/17/26	2:35 PM	EB	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/17/26	2:35 PM	EB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor