



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 012

Customer

Facility Name: Atrium

Address: 307 South Dithridge
Pittsburgh, PA 15213

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/17/26

Time: 2:00 PM

Method: Grab

Sample Final Analysis

Date: 8/20/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/18/26	10:25 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/18/26	10:25 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/17/26	4:45 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	8/17/26	2:00 PM	AG	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/17/26	2:00 PM	AG	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/17/26	2:00 PM	AG	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)