



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 438

Customer

Facility Name: Blackhawk H.S.
Address: 500 Blackhawk Rd.
Beaver Falls, PA 15010

Sample Collection

Date: 8/17/26
Time: 4:31 PM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 8/20/26
Time: 11:30 AM
Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/18/26 11:25 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/18/26 11:25 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/17/26 6:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/17/26 4:31 PM	AMH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/17/26 4:31 PM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/17/26 4:31 PM	AMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor