



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 2628

Customer

Facility Name: Buena Vista Fire Company

Address: 3333 Fire Station St.
Buena Vista, PA 15018

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/18/26

Time: 12:35 PM

Method: Grab

Sample Final Analysis

Date: 8/21/26

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/19/26	9:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/19/26	9:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/18/26	4:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/18/26	12:35 PM	LL	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/18/26	12:35 PM	LL	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/18/26	12:35 PM	LL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor