



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-13

Lab# 490

Customer

Facility Name: *Center for Fitness and Health*

Address: *800 Plaza Dr. Suite 100*
Bell Vernon. Pa 15012

Matrix: *Center for Fitness and Health*

Source Type: *Therapy Pool*

Sample Collection

Date: *8/17/26*

Time: *9:20 AM*

Method: *Grab*

Sample Final Analysis

Date: *8/20/26*

Time: *11:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/18/26	10:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/18/26	10:50 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/17/26	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/17/26	9:20 AM	SH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/17/26	9:20 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/17/26	9:20 AM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor