



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665

Lab ID No. 02-04041

E - 12

Lab# 060

Laboratory Analysis Report

Customer

Facility Name: Comfort Inn
Address: 699 Rodi Road
Pittsburgh, PA 15235

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/17/26
Time: 12:42 PM
Method: Grab

Sample Final Analysis

Date: 8/20/26
Time: 12:00 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/18/26	11:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/18/26	11:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	8/17/26	6:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/17/26	12:42 PM	DW	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/17/26	12:42 PM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/17/26	12:42 PM	DW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor