



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-11

Lab# 085

Customer

Facility Name: Deer Lakes H.S.
Address: 163 East Union Road
Cheswick, PA 15024

Sample Collection

Date: 8/18/26
Time: 2:30 PM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 8/21/26
Time: 9:30 AM
Analyst: AS

Source Type: Shallow End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/19/26	9:00 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/19/26	9:00 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	8/18/26	4:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/18/26	2:30 PM	SH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/18/26	2:30 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/18/26	2:30 PM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor