



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-13

Lab# 101

Customer

Facility Name: *Fairfield Inn & Suites*
Address: *901 Providence Blvd.*
McCandless, PA 15237

Sample Collection

Date: *8/18/26*
Time: *11:15 AM*
Method: *Grab*

Matrix: *Recreational Water*

Sample Final Analysis

Date: *8/21/26*
Time: *9:30 AM*
Analyst: *AS*

Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/19/26	9:00 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/19/26	9:00 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	8/18/26	4:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/18/26	11:15 AM	IS	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	8/18/26	11:15 AM	IS	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/18/26	11:15 AM	IS	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)