



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 167

Customer

Facility Name: Home 2 Suites
Address: 1401 Cranberry Woods Dr.
Cranberry, PA 16066

Sample Collection

Date: 8/20/26
Time: 1:09 PM
Method: Grab

Sample Final Analysis

Date: 8/22/26
Time: 5:30 PM
Analyst: AS

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/20/26	5:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/20/26	5:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	8/20/26	5:00 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	1/0/00	12:00 AM	0	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/20/26	1:09 PM	EG	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/20/26	1:09 PM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/20/26	1:09 PM	EG	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)