



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-12

Lab# 2286

Customer

Facility Name: *Ingomar North Swim Club*

Address: *460 Olive Street
Pittsburgh, PA 15237*

Matrix: *Recreational Water*

Source Type: *Shallow End*

Sample Collection

Date: *8/17/26*

Time: *10:35 AM*

Method: *Grab*

Sample Final Analysis

Date: *8/20/26*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/18/26	9:55 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/18/26	9:55 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/17/26	4:45 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/17/26	10:35 AM	IS	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/17/26	10:35 AM	IS	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/17/26	10:35 AM	IS	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)