



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 505

Customer

Facility Name: *Riverside High School*
Address: *300 Counntry Club Dr.*
Ellwood City, PA 16117

Sample Collection

Date: *8/20/26*
Time: *10:35 AM*
Method: *Grab*

Sample Final Analysis

Date: *8/22/26*
Time: *5:30 PM*
Analyst: *AS*

Matrix: *Riverside High School*
Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/20/26	5:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/20/26	5:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	8/20/26	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/20/26	10:35 AM	EG	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/20/26	10:35 AM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/20/26	10:35 AM	EG	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)