



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 2466

Customer

Facility Name: Sandcastles Water Park

Address: 1000 Sandcastle Drive
Homestead, PA 15120

Matrix: Recreational Water

Source Type: Wave Deep

Sample Collection

Date: 8/19/26

Time: 9:38 AM

Method: Grab

Sample Final Analysis

Date: 8/22/26

Time: 11:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/20/26	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/20/26	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/19/26	6:35 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/19/26	9:38 AM	SL	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	8/19/26	9:38 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/19/26	9:38 AM	SL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)