



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 503

Customer

Facility Name: University of Pgh Recreation

Address: 3719 Terrace St.
Pittsburgh, PA 15213

Matrix: University of Pgh Recreation

Source Type: Pool

Sample Collection

Date: 8/18/26

Time: 11:07 AM

Method: Grab

Sample Final Analysis

Date: 8/21/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/19/26	10:00 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/19/26	10:00 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	8/18/26	5:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/18/26	11:07 AM	JT	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/18/26	11:07 AM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/18/26	11:07 AM	JT	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor