



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-13

Lab# 2557

Customer

Facility Name: Virginia Hills West
Address: 200 Falls Church Rd.
Imperial, PA 15126

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/19/26
Time: 9:20 AM
Method: Grab

Sample Final Analysis

Date: 8/22/26
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/20/26	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/20/26	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/19/26	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/19/26	9:20 AM	AMH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/19/26	9:20 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/19/26	9:20 AM	AMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)