



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2608

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Yards @ 3 Crossings*

Address: *2645 Railroad St.*
Pittsburgh, PA 15222

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *8/18/26*

Time: *9:56 AM*

Method: *Grab*

Sample Final Analysis

Date: *8/21/26*

Time: *11:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/19/26	10:55 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/19/26	10:55 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/18/26	6:00 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	8/19/26	12:00 PM	AH	SM 9230C
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/18/26	9:56 AM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/18/26	9:56 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/18/26	9:56 AM	SL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)