



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2105

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Christopher Wren Apt.*
Address: *501 Christopher Wren Dr.*
Wexford, PA 15090

Sample Collection

Date: *8/18/26*
Time: *9:45 AM*
Method: *Grab*

Matrix: *Recreational Water*

Sample Final Analysis

Date: *8/21/26*
Time: *9:30 AM*
Analyst: *AS*

Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/19/26	9:00 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/19/26	9:00 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	8/18/26	4:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/18/26	9:45 AM	IS	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	8/18/26	9:45 AM	IS	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/18/26	9:45 AM	IS	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)