



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 2725

Customer

Facility Name: Sunrise Acres
Address: 201 Noble Circle
Valencia, PA 16059

Sample Collection

Date: 8/17/26
Time: 2:26 PM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 8/20/26
Time: 12:00 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/18/26	11:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/18/26	11:50 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/17/26	6:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/17/26	2:26 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/17/26	2:26 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/17/26	2:26 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor