



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 270

Customer

Facility Name: Science and Technology Academy
Address: 107 Thackeray St.
Pittsburgh, PA 15213

Sample Collection

Date: 8/17/26
Time: 12:20 PM
Method: Grab

Matrix: Recreational Water
Source Type: Pool Shallow

Sample Final Analysis

Date: 8/20/26
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	8/18/26	8:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	A	8/18/26	8:30 AM	AH	SM 9222B
Standard plate count:	0/ml	A	8/17/26	3:42 PM	AH	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.4 SU	A	8/17/26	12:20 PM	JT	DPD
Chlorine:	2.0 mg/l	B	8/17/26	12:20 PM	JT	DPD
Turbidity:	1 NTU	A	8/17/26	12:20 PM	JT	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)