

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9554567, 9551095

Month July, 2023				Day : Monday				Date : 10.07.23					
Probable Maximum Demand : 14800 MW				Probable Maximum Generation : 14605 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 74.97 ft		Today = 75.24 ft		Rule Curve = 85.28 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dered/ Present Capacity (MW)	09.07.23 (Yesterday)		10.07.23 (Today)		09.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW				
					Day	Evening	Day	Evening	Machines shut down (MW)	Description/ Remarks		Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	120	130	130	130				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	170	170				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	342	337	330	330				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	405	395	400	400				
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	117	195	155	155				
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	322	328	320	320				
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	304	286	310	310				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	84	24	102				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	19	19				
17	Summit Power, (Madhabdi-Ashulia)	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	42	32	37	37				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	24	24	24				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	82	130	82	150				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	293	276	293	293				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	132	130	135	135				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	211	300	300	300				
27	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
28	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
29	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
30	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	72	54	73				
31	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	144	17	162				
32	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	34	0	30	0				
33	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	35				
34	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	50	50	50	50				
35	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	63	37	55	55				
36	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	80	80	80	80				
37	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	100	75	36	25	75				
Dhaka Zone Total			6004	5822	3668	4083	3795	4210	213	375			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	60	60	30	60	170	Low water level		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	104	105	110	110	75	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	50	6	50				
44	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	34	40	34	40				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	220	225	225	225				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	88	264	88	280				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	60	100	50	88				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	32	33	33	33				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	23	64	32	64				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	11	11	11				
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			2	30	15	30				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	7	18	12	30				
53	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	36	17	34				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	50	76	50	75				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRP)	8x13.45	100	100	58	70	58	70				
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	51	34	51				
58	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	53	160	54	163				
SS	Power Unit-1	Coal (IPP)				0	0	0	0				
	Cox's Bazar Wind PP	(Wind) (IPP)				2	5	15	10				
Chattogram Zone Total			2605	2545	910	1432	924	1458	245	330			
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	43	45	44	44				
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	188	212	200	210				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360	Under maint.		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	305	310	330	330				
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	401	401	350	350				
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	78	78	78	78	117	Gas Shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	144	5	150				
67	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	45	44	45				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	55	109	50	120				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	18	18	18				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	11	10	10				
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	42	42	42				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20				
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	52	106	52	106				
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	68	9	68				
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	95	55	94				
**	limport (Tripura)	India		160	160	142	158	129	152				
Cumilla Zone Total			2904	2896	1558	1955	1529	1930	117	523			
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	17	32	30	35	170	Gas Shortage		
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	18	18	18				
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	20	85				
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	69	88	68	88				
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0				
84	Sutiekhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	33	0	50	0				
85	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12				
Mymensingh Zone Total			622	614	166	235	200	238	170	0			

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.07.23 (Yesterday)		10.07.23 (Today)		09.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Machines shut down (MW)			
86	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	GT-1 & ST-1 Under maint.	
87	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	38	39	39	39	51	GT-4 Under maint.	
88	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	45	45	45	45			
89	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112	54	ST Under maint.	
90	Hobgiri 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	5	5	5			
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	60	60			
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	86	86	86			
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	57	164	204	204			
95	Sylhet 20 MW GTTP	Gas (PDB)	1x 20	20	20	17	18	17	18			
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24			
98	Bibiara-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	275	300	300			
99	Bibiara-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	403	402	0	0			
100	Bibiara South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	356	380	376	380			
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
102	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	47	47	44	44			
Sylhet Zone Total					2472	2427	1599	1711	1365	1370	0	562
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
104	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	185	170	150	155			
105	Fairdip 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	10	29	20	33			
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	17	61	36	70			
107	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	150	225			
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	32	55	35	55			
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	67	25	68			
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	22	0	100	0			
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	78	95	80	95			
112	Noapara 40 MW PP (Khanaihan Ali)	HFO (NENP)	5*8.5	40	40	8	32	8	40			
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	300			
114	Khulna 330 MW CAPP (GT)	Gas/HSD (PDB)	1x220	220	220	0	0	0	0			
**	Bheramara (HVDC)	India		1000	1000	909	907	923	923			
Khulna Zone Total					3125	3121	1276	1527	1964	0	0	
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	98	100	100	100			
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	24	35	25	27			
117	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	134	130	130	130			
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	610	622	622	622	622	Coal Shortage	
119	Potukhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150			
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307	Coal Shortage	
121	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	221	224	220	220			
Barishal Zone Total					2265	2265	1104	1261	1114	1249	929	0
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0			
123	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	140	150	200			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0			
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	90	0	90			
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	27	22	27			
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	25	34	34	34			
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	35	35			
131	Sirajganj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Under Maint.	
132	Sirajganj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	126	132	128	132			
133	Sirajganj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	134	129	128	129			
134	Sirajganj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	364	340	340	340			
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0			
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8			
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50			
140	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	28	28	28	28			
141	Sirajganj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0			
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	615	614	600	600			
Rajshahi Zone Total					2927	2905	1372	1725	1549	1771	0	310
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	180	180	230	230	94	Coal Shortage	
145	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	97	34	70			
147	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
148	Majma. Talsia 9 MW Solar PP (Syma Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0			
149	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	119	115	36	115	35	115			
150	Lalmohar 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	0	30	0	0			
151	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	82	0	130	0			
Rangpur Zone Total					1030	950	377	392	467	415	179	85
Sub-total: Plants in operation					23954	23545	12030.0	14210	12470	14605	1853	2185
(B) Plants under long term maintenance/ contract expired												
152	Jamapur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
153	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
154	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
155	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired					309	0	0	0	0	0	0	0
Gross Total					24263	23545	12030	14210	12470	14605	1853	2185
(C) Actual data of 09.07.23 (Yesterday) Sunday :												
01.	Max. Demand at eve. peak (Generation end)	:	14850 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	14172 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	14210 MW, at =	21:00 hrs	Dhaka	4776	4776	0	Mymensingh	1213	1093	120
04.	Minimum Generation (Generation end)	:	11409 MW, at =	8:00 hrs	Chattogram	1368	1368	0	Sylhet	517	446	71
05.	Day-peak-generation (Generation end)	:	12030 MW, at =	12:00 hrs	Khulna	1867	1707	160	Barishal	490	490	0
06.	Evening-peak Generation (Generation end)	:	14210 MW, at =	21:00 hrs	Rajshahi	1551	1471	80	Rangpur	964	864	100
07.	Evening Peak Load-shed (Sub-station end)	:	611 MW, at =	21:00 hrs	Cumilla	1425	1345	80				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10967 MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:										
	a) Gas/LF limitation	:	1504 MW									
	d) Coal supply Limitation	:	179 MW									
	b) Low water level in Kaptai lake	:	170 MW									
	c) Plants under shut down/ maintenance	:	2185 MW									
10.	Total Energy (Generation + India Import)	:	299.05 MKWh									
	By Gas = 162.131 MKWh	By Oil =	71.191 MKWh									
	By Coal = 36.344 MKWh	By Hydro =	1.063 MKWh									
	By Solar= 2.525 MKWh											
11.	Total Gas Supplied	:	1215.87 MMCFD									
(D) Forecast of 10.07.23 (Today) Monday :												
01.	Maximum Demand	:	14800 MW	(Generation end)	04.	Maximum Load-shed	:	180 MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	14605 MW	(Generation end)	05.	Total Generation	:	311.46 MKWh				
03.	Reserve / Shortage	:	-195 MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	34.4° C				

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation