



ICAO ENGINE EXHAUST EMISSIONS DATA BANK

SUBSONIC ENGINES

ENGINE IDENTIFICATION: CF6-80C2B6
UNIQUE ID NUMBER: 1GE029
ENGINE TYPE: TF

BYPASS RATIO: 5.1
PRESSURE RATIO (π_{oo}): 31.56
RATED OUTPUT (F_{oo}) (kN): 267.2

REGULATORY DATA

CHARACTERISTIC VALUE:	HC	CO	NOx	SMOKE NUMBER
D_p/F_{oo} (g/kN) or SN	14.5	59.7	50.9	9.1
AS % OF ORIGINAL LIMIT	73.8 %	50.6 %	49.3 %	50.6 %
AS % OF CAEP/2 LIMIT (NOx)			61.7 %	
AS % OF CAEP/4 LIMIT (NOx)			72.5 %	
AS % OF CAEP/6 LIMIT (NOx)			81.9 %	
AS % OF CAEP/8 LIMIT (NOx)			95.6 %	

DATA STATUS

- PRE-REGULATION
x CERTIFICATION
- REVISED (SEE REMARKS)

TEST ENGINE STATUS

x NEWLY MANUFACTURED ENGINES
- DEDICATED ENGINES TO PRODUCTION STANDARD
- OTHER (SEE REMARKS)

EMISSIONS STATUS

x DATA CORRECTED TO REFERENCE
(ANNEX 16 VOLUME II)

CURRENT ENGINE STATUS

(IN PRODUCTION, IN SERVICE UNLESS OTHERWISE NOTED)
x OUT OF PRODUCTION (DATE: -)
- OUT OF SERVICE

MEASURED DATA

MODE	POWER SETTING (% F_{oo})	TIME minutes	FUEL FLOW kg/s	EMISSIONS INDICES (g/kg)			SMOKE NUMBER
				HC	CO	NOx	
TAKE-OFF	100	0.7	2.579	0.07	0.52	30.81	7.8
CLIMB OUT	85	2.2	2.081	0.08	0.52	22.94	5.4
APPROACH	30	4.0	0.686	0.2	1.93	9.11	2.3
IDLE	7	26.0	0.207	8.99	41.66	3.79	3
LTO TOTAL FUEL (kg) or EMISSIONS (g)			871	2966	13970	12362	-
NUMBER OF ENGINES				2	2	2	2
NUMBER OF TESTS				3	3	3	3
AVERAGE D_p/F_{oo} (g/kN) or AVERAGE SN (MAX)				11.12	52.36	46.26	7.8
SIGMA (D_p/F_{oo} in g/kN, or SN)				1.3	3.03	2.16	1.3
RANGE (D_p/F_{oo} in g/kN, or SN)				10.02-12.49	49.74-55.21	44.57-48.88	6.1-8.4

ACCESSORY LOADS

POWER EXTRACTION 0 (kW) AT - POWER SETTINGS
STAGE BLEED 0 % CORE FLOW AT - POWER SETTINGS

ATMOSPHERIC CONDITIONS

BAROMETER (kPa)	97.40-97.82
TEMPERATURE (K)	287 - 296
ABS HUMIDITY (kg/kg)	.0084-.0140

FUEL

SPEC	Jet A
H/C	1.94
AROM (%)	15.3

MANUFACTURER: GE Aircraft Engines
TEST ORGANIZATION: CF6 Evaluation Engineering
TEST LOCATION: Site IIIC, PTO, Peebles, Ohio
TEST DATES: FROM 29 May 85 TO 03 Jun 85

REMARKS

1. Ref GE Report R86AEB160.
2. Engine S/N's 690105 and 690005/2.

If REVISED, this data supersedes databank UID
Compliance with fuel venting requirements:

0 ('x' if complies, PR if pre-regulation)