

ICAO ENGINE EXHAUST EMISSIONS DATA BANK

SUBSONIC ENGINES

ENGINE IDENTIFICATION: CFM56-5B3/2P BYPASS RATIO: 5.6 PRESSURE RATIO $(\pi_{\circ\circ})$: 32.8 UNIQUE ID NUMBER: 4CM038 RATED OUTPUT $(F_{\circ\circ})$ (kN): 142.4 ENGINE TYPE: TF

REGULATORY DATA

CHARACTERISTIC VALUE:	НC	СО	NOx	SMOKE NUMBER
D_p/F_{oo} (g/kN) or SN	7.3	71.5	49.4	2.6
AS % OF ORIGINAL LIMIT	37.0 %	60.6 %	46.8 %	12.3 %
AS % OF CAEP/2 LIMIT (NOx)			58.5 %	
AS % OF CAEP/4 LIMIT (NOx)			68.1 %	
AS % OF CAEP/6 LIMIT (NOx)			76.5 %	
AS % OF CAEP/8 LIMIT (NOx)			88.7 %	

DATA STATUS

PRE-REGULATION

CERTIFICATION

REVISED (SEE REMARKS)

TEST ENGINE STATUS

- NEWLY MANUFACTURED ENGINES

DEDICATED ENGINES TO PRODUCTION STANDARD

OTHER (SEE REMARKS)

EMISSIONS STATUS

DATA CORRECTED TO REFERENCE

(ANNEX 16 VOLUME II)

CURRENT ENGINE STATUS

(IN PRODUCTION, IN SERVICE UNLESS OTHERWISE NOTED)

OUT OF PRODUCTION (DATE: -)

OUT OF SERVICE

MEASURED DATA

	POWER	TIME	FUEL FLOW	EMI	SSIONS INDICES	(g/kg)	
MODE	SETTING	minutes	kg/s	HC	CO	NOx	SMOKE NUMBER
	(%F ₀₀)						
TAKE-OFF	100	0.7	1.470	0.1	0.6	32	0.5
CLIMB OUT	85	2.2	1.150	0.1	1.3	18.6	0.3
APPROACH	30	4.0	0.400	2.9	19.9	7.8	0.5
IDLE	7	26.0	0.130	2.5	34.5	4.3	2.3
LTO TOTAL FUEL (kg) or EMISSIONS (g) 512				807	9141	6420	_
NUMBER OF ENGINES				2	2	2	2
NUMBER OF TESTS				4	4	4	4
AVERAGE D _p /F _{oo} (g/kN) or AVERAGE SN (MAX)			5.57	62.79	44.93	2.25	
SIGMA (D_p/F_{oo} in g/kN , or SN)				-	-	_	-
RANGE $(D_p/F_{oo} \text{ in } g/kN, \text{ or } SN)$			5.1-6.0	59.3-66.3	44.3-45.5	2.1-2.4	

ACCESSORY LOADS

A EXTRACTION STAGE BLEED (kW) % CORE FLOW POWER EXTRACTION 0 AΤ POWER SETTINGS POWER SETTINGS

ATMOSPHERIC CONDITIONS

BAROMETER (kPa)	98.5-99.74		
TEMPERATURE (K)	284.6-292.4		
ABS HUMIDITY (kg/kg)	.00810115		

FUEL

SPEC	Jet A
H/C	1.93
AROM (%)	17.33

MANUFACTURER: CFM International

MANUFACTURER: CFM International
TEST ORGANIZATION: GEAE Peebles Testing Facility + Techspace Aero (CFMI)
Peebles. Ohio. USA + Liers, Belgium

TEST ORGANIZATION: Peeples, FROM Aug 96 Peebles, Ohio, USA + Liers, Belgium TO Sep 96

REMARKS

DAC-II Combustor P/N 1968M99G04

If REVISED, this data supersedes databank UID Compliance with fuel venting requirements:

0 ('x' if complies, PR if pre-regulation)