



A P P R O V A L S ®

Certificate of Conformity/Approval

Certificate No.: SAA-172141-EA

Certificate Holder: People Ele. Appliance Group Zhejiang Import & Export Corp.
People Industry Zone, No.555 Chezhan Road,
Liushi, Yueqing,
Zhejiang Province 325604
P.R. China

Regulatory Definition: Residual Current Device

Product Description: RCBO

Standard/s: AS/NZS 61009.1:2015

Condition/s: Not for use in New Zealand.

Approval Marks: RCM (In accordance with AS/NZS 4417 and EESS requirements)
and
SAA-172141-EA (In accordance with NSW legislative requirements)

Initial Issue Date: 5 September 2017

Expiry Date: 5 September 2027


R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 23-08-22 172141
Renewed Page 1 of 17



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
RDL8-40 (A4030C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=40A, Type C IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A3230C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=32A, Type C IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A2530C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=25A, Type C IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A2030C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=20A, Type C IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A1630C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=16A, Type C IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A1030C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=10A, Type C IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A0630C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=6A, Type C IΔn=30mA Type A Icn=Ics=6000A

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 23-08-22 172141
Renewed Page 2 of 17



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
RDL8-40 (A40100C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=40A, Type C IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A32100C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=32A, Type C IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A25100C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=25A, Type C IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A20100C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=20A, Type C IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A16100C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=16A, Type C IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A10100C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=10A, Type C IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A06100C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=6A, Type C IΔn=100mA Type A Icn=Ics=6000A

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 23-08-22 172141
Renewed Page 3 of 17



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
RDL8-40 (AC4030C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=40A, Type C IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC3230C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=32A, Type C IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC2530C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=25A, Type C IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC2030C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=20A, Type C IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC1630C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=16A, Type C IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC1030C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=10A, Type C IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC0630C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=6A, Type C IΔn=30mA Type AC Icn=Ics=6000A

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 23-08-22 172141
Renewed Page 4 of 17



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
RDL8-40 (AC40100C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=40A, Type C IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC32100C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=32A, Type C IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC25100C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=25A, Type C IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC20100C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=20A, Type C IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC16100C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=16A, Type C IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC10100C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=10A, Type C IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC06100C2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=6A, Type C IΔn=100mA Type AC Icn=Ics=6000A

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 23-08-22 172141
Renewed Page 5 of 17



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
RDL8-40 (A4030C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=40A, Type C IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A3230C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=32A, Type C IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A2530C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=25A, Type C IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A2030C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=20A, Type C IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A1630C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=16A, Type C IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A1030C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=10A, Type C IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A0630C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=6A, Type C IΔn=30mA Type A Icn=Ics=6000A

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 23-08-22 172141
Renewed Page 6 of 17



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
RDL8-40 (A40100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=40A, Type C IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A32100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=32A, Type C IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A25100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=25A, Type C IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A20100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=20A, Type C IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A16100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=16A, Type C IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A10100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=10A, Type C IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A06100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=6A, Type C IΔn=100mA Type A Icn=Ics=6000A

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 23-08-22 172141
Renewed Page 7 of 17



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
RDL8-40 (AC4030C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=40A, Type C IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC3230C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=32A, Type C IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC2530C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=25A, Type C IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC2030C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=20A, Type C IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC1630C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=16A, Type C IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC1030C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=10A, Type C IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC0630C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=6A, Type C IΔn=30mA Type AC Icn=Ics=6000A

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 23-08-22 172141
Renewed Page 8 of 17



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
RDL8-40 (AC40100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=40A, Type C IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC32100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=32A, Type C IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC25100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=25A, Type C IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC20100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=20A, Type C IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC16100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=16A, Type C IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC10100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=10A, Type C IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC06100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=6A, Type C IΔn=100mA Type AC Icn=Ics=6000A

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 23-08-22 172141
Renewed Page 9 of 17



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
RDL8-40 (A4030B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=40A, Type B IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A3230B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=32A, Type B IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A2530B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=25A, Type B IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A2030B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=20A, Type B IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A1630B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=16A, Type B IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A1030B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=10A, Type B IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A0630B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=6A, Type B IΔn=30mA Type A Icn=Ics=6000A

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 23-08-22 172141
Renewed Page 10 of 17



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
RDL8-40 (A40100B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=40A, Type B IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A32100B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=32A, Type B IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A25100B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=25A, Type B IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A20100B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=20A, Type B IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A16100B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=16A, Type B IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A10100B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=10A, Type B IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A06100B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=6A, Type B IΔn=100mA Type A Icn=Ics=6000A

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 23-08-22 172141
Renewed Page 11 of 17



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
RDL8-40 (AC4030B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=40A, Type B IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC3230B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=32A, Type B IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC2530B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=25A, Type B IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC2030B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=20A, Type B IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC1630B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=16A, Type B IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC1030B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=10A, Type B IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC0630B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=6A, Type B IΔn=30mA Type AC Icn=Ics=6000A

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 23-08-22 172141
Renewed Page 12 of 17



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
RDL8-40 (AC40100B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=40A, Type B IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC32100B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=32A, Type B IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC25100B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=25A, Type B IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC20100B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=20A, Type B IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC16100B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=16A, Type B IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC10100B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=10A, Type B IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC06100B2)	PEOPLE	Ue= 240V~(1P+N) 50/60Hz In=6A, Type B IΔn=100mA Type AC Icn=Ics=6000A

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 23-08-22 172141
Renewed Page 13 of 17



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
RDL8-40 (A4030C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=40A, Type B IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A3230C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=32A, Type B IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A2530C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=25A, Type B IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A2030C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=20A, Type B IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A1630C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=16A, Type B IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A1030C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=10A, Type B IΔn=30mA Type A Icn=Ics=6000A
RDL8-40 (A0630C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=6A, Type B IΔn=30mA Type A Icn=Ics=6000A

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 23-08-22 172141
Renewed Page 14 of 17



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
RDL8-40 (A40100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=40A, Type B IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A32100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=32A, Type B IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A25100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=25A, Type B IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A20100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=20A, Type B IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A16100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=16A, Type B IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A10100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=10A, Type B IΔn=100mA Type A Icn=Ics=6000A
RDL8-40 (A06100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=6A, Type B IΔn=100mA Type A Icn=Ics=6000A

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 23-08-22 172141
Renewed Page 15 of 17



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
RDL8-40 (AC4030C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=40A, Type B IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC3230C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=32A, Type B IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC2530C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=25A, Type B IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC2030C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=20A, Type B IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC1630C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=16A, Type B IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC1030C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=10A, Type B IΔn=30mA Type AC Icn=Ics=6000A
RDL8-40 (AC0630C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=6A, Type B IΔn=30mA Type AC Icn=Ics=6000A

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 23-08-22 172141
Renewed Page 16 of 17



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating / Marking
RDL8-40 (AC40100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=40A, Type B IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC32100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=32A, Type B IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC25100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=25A, Type B IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC20100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=20A, Type B IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC16100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=16A, Type B IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC10100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=10A, Type B IΔn=100mA Type AC Icn=Ics=6000A
RDL8-40 (AC06100C4)	PEOPLE	Ue= 415V~(3P+N) 50/60Hz In=6A, Type B IΔn=100mA Type AC Icn=Ics=6000A

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 23-08-22 172141
Renewed Page 17 of 17