

AI Equipment Intelligence Incident Report

Timestamp: 07:51:50 | Plant Status: WARNING (Health: 82/100)

Asset Component	Primary Metric	Health Score	Condition
Centrifugal Pump	78.15% Wire-to-Water Eff	100/100	Optimal
Recip/Centrif Compressor	17.29 kW/100CFM	100/100	Optimal
Shell & Tube HEX	1035.45 kW Thermal Duty	99/100	Optimal
Chiller & Cooling Tower	0.75 kW/TR	32/100	Critical

Triggered Diagnostic Advisories:

- [Chiller/Tower] High Specific Power (0.75 kW/TR): Scaling suspected
- [Chiller/Tower] Excessive Tower Approach (7.0°C)
- [Chiller/Tower] High Cycles of Concentration (7.7): Scaling risk
- [ML DRIFT ALERT] Multivariate Isolation Forest detected an operational drift pattern.