

Digging for the Sun: Superhot Rock Geothermal as the World-Scale Source of Clean Baseload Power

Bartosz Osiej*

August 17, 2026

ABSTRACT

The energy transition has solved the *cheap* problem (wind and solar) and, with long-duration storage of the iron–air class, is solving the *multi-day* problem—but the *baseload* problem remains: every decarbonized grid still needs firm, dispatchable power for weeks-long lulls, industrial heat, and energy security, and the only candidates are nuclear, fossil-with-capture, and geothermal. This paper presents a comprehensive review and an original quantitative feasibility analysis of the most ambitious of these: *superhot rock* (SHR) geothermal, the extraction of heat from rock at 374 °C and above—beyond the supercritical point of water—reached by drilling 5–20 km into the Earth. At such conditions a single well can deliver an order of magnitude more power than a conventional geothermal well, because supercritical water carries 3–10× the enthalpy per kilogram and flows through natural or engineered fracture networks with far lower viscosity.

The resource is effectively unlimited: the Clean Air Task Force estimates that just 1% of the United States’ superhot rock resource could provide 4.3 TW of capacity—several times the country’s entire electricity demand—and superhot temperatures exist everywhere on Earth at sufficient depth, unlike conventional hydrothermal fields. The bottleneck is not geology but *drilling*: conventional bits and electronics fail above ~250 °C, and cost scales sharply with depth. We review the emerging drilling solutions (gyrotron millimeter-wave vaporization, plasma and laser spallation, flame jets), the subsurface engineering of fracture networks and induced-seismicity management, and the surface power cycle (including supercritical CO₂ turbines). We then build a transparent techno-economic model for a 100 MW superhot plant. The honest central estimate is 66 \$MW⁻¹ h to 90 \$MW⁻¹ h at today’s drilling costs—competitive with gas combined cycle, but not transformative; it falls to ~45 \$MW⁻¹ h only if the DOE Enhanced Geothermal Shot’s 90% drilling-cost reduction is achieved, and we quantify exactly which lever matters (the well field). With 24/7 availability and zero fuel, and a sensitivity analysis over drilling cost, capital, capacity factor, and discount rate, we conclude that superhot rock is a credible world-scale baseload source *if* its drilling learning curve is delivered. An honest risk assessment covers drilling-cost uncertainty at 20 km, seismicity, corrosion, water use, and timeline risk. We conclude that superhot rock geothermal is the most credible path to terawatt-scale, anywhere-on-Earth clean baseload, and that it is the natural complement to the storage technologies analyzed in the author’s companion studies.

Keywords: superhot rock, supercritical geothermal, enhanced geothermal systems, gyrotron drilling, baseload power, clean firm power, levelized cost of electricity, induced seismicity, supercritical CO₂ cycle

PACS: 91.35.Lj, 91.55.Jk, 44.10.+i, 84.60.Rb, 89.30.-g

*Independent Researcher, Szczecin, Poland. E-mail: mmc29213@gmail.com

1 Introduction: The Baseload Gap

Variable renewables plus storage solve two of the three problems of decarbonization. Solar and wind solve the cost problem; multi-day storage of the iron–air class analyzed in a companion study by the author solves the *dunkelflaute* problem—gaps of three to five days. What remains is the *baseload* problem, and it is quantitative:

- **Weeks-long lulls and seasonal imbalance.** Even with 100-hour storage, a grid needs something to bridge winter weeks of low wind and sun, or to charge that storage in the first place. Firm capacity is required at 50–100% of peak demand in every credible deep-decarbonization scenario [1, 14].
- **Industrial heat.** Steel, cement, chemicals, and ammonia need heat at 400–1,500 °C, around the clock. Electrification with heat pumps cannot reach these temperatures; the world’s industrial heat demand is ~50% of final energy use [12].
- **Energy security and grid services.** Inertia, voltage support, and black-start capability come naturally from spinning or synchronous machines; batteries and inverters must be told to provide them.
- **Land and public acceptance.** Solar and wind are land-hungry; a firm clean technology with a footprint of ~10 hectares per 100 MW and no visible exhaust is politically valuable.

The candidates for firm clean power are few: nuclear fission (decades-long build times, public acceptance), fossil with carbon capture (expensive, still fossil), biomass (limited), and *geothermal*. Conventional hydrothermal geothermal already provides roughly 16 GW and 100 TWh/yr worldwide, but only where nature supplied hot water [13]. **Superhot rock** (SHR) removes that geographic limitation: drill deep enough—5–20 km—and the temperature exceeds the supercritical point of water (374 °C, 221 bar) almost anywhere on Earth. At those conditions the physics changes qualitatively, and a single well can produce ten times the power of a conventional well [4].

The question this paper answers: is superhot rock the world-scale breakthrough that closes the baseload gap—and what exactly stands between the concept and terawatt-scale reality? The honest short answer: the concept is sound, the resource is enormous, the economics are credible, and the one true bottleneck is *drilling*.

2 The Resource: Physics of the Earth’s Heat

2.1 Temperature Gradient and Depths

The Earth conducts heat outward at a crustal average of ~60–100 mW/m². Away from volcanic provinces the geothermal gradient is ~25–30 °C/km, so 374 °C—the supercritical point of water—is reached near 12–15 km in normal crust, 6–8 km in regions with above-average gradients, and 3–5 km in volcanic zones such as Iceland (Fig. 1). The Iceland Deep Drilling Project proved the concept: IDDP-1 (2009) encountered 452 °C superheated steam, and IDDP-2 (2016–2017) reached 465 °C at 4.5 km; the follow-on IDDP-3 targets fluid enthalpy above 3,000 kJ/kg [3, 1].




Figure 1: Temperature versus depth for three crustal gradients, with the supercritical boundary of water marked. Superhot conditions are reached at 12–15 km in normal crust but at 3–5 km in volcanic provinces.

2.2 Why Supercritical Water Changes Everything

The advantage of superhot conditions is thermodynamic, and it is large. Water at supercritical conditions (above 374 °C and 221 bar) is neither liquid nor gas: it has gas-like viscosity and liquid-like density, and it carries enormously more enthalpy per kilogram. Concretely [4, 3]:

- **Enthalpy:** conventional geothermal brine delivers ~1,000 kJ/kg; supercritical fluid up to 3,000+ kJ/kg—3–5× per kilogram.
- **Flow:** the low viscosity of supercritical water allows much higher mass flow through the same fracture network—the combined effect is an order of magnitude more power per well.
- **Power per well:** a superhot well can produce 20–50 MW (thermal) versus 2–5 MW for a conventional high- temperature well; Iceland’s IDDP-1, from a single *partial* test, was estimated capable of ~36 MWe.

The arithmetic is the same one that drives the whole SHR case: going supercritical multiplies the power per meter of drilling, which is what makes deep drilling—expensive per meter—economically viable.

2.3 The Supercritical Transition in Detail

Figure 2 shows why the *transition* itself matters, not just the high temperature. At a fixed pressure above the critical point (~250 bar), the specific enthalpy of water rises gently with temperature up to ~350 °C, and then nearly *verticalizes*: passing through the pseudo-critical region (~385 °C at 250 bar), the fluid acquires gas-like viscosity while retaining liquid-like density, and the enthalpy jumps by roughly a third in a span of tens of degrees. The practical consequences are those already quoted: a supercritical well produces 3–5× the enthalpy per kilogram and, because the low viscosity allows far higher flow, an order of magnitude more power per well than a conventional 250 °C well. The values plotted are standard steam-table data for pure water at 250 bar; real geothermal fluids (with dissolved silica and salts) shift the numbers but not the shape.




Figure 2: Specific enthalpy of water at 250 bar versus temperature. Above the critical point (374 °C, 221 bar) the enthalpy rises steeply through the pseudo-critical region—the thermodynamic reason a superhot well carries 3–5× more energy per kilogram than a conventional 250 °C well. Values from standard steam tables.

2.4 The Resource Arithmetic

The superhot resource is not a depletable field but a boundary condition of the crust. The Clean Air Task Force’s heat mapping estimates that *just 1% of the US superhot rock resource accessible below 20 km could provide 4.3 TW of capacity*—several times current US electricity demand—and the resource exists beneath nearly the entire country, not just the West [1]. The same logic holds globally: superhot temperatures are a function of depth and gradient, not of rare geology, so the resource is effectively unlimited [11, 12]. The constraint is extraction cost, not availability.

Table 1: Three generations of geothermal technology.

Generation	Depth	Temperature	Water	Status	Power/well
Hydrothermal	1–3 km	150–300 °C	Natural	Commercial (~16 GW)	2–5 MWe
Enhanced (EGS)	3–8 km	175–250 °C	Injected (frac)	Commercial since 2023 (Fervo)	3–10 MWe
Superhot (SHR)	5–20 km	374–500 °C	Injected (su- percritical)	Pilots 2026–2035	20–50 MWe

3 From Hydrothermal to EGS to Superhot

Conventional hydrothermal geothermal exploits natural reservoirs of hot water; it is mature, but geographically confined to volcanic margins (Iceland, Indonesia, Philippines, East Africa, western US, New Zealand). Enhanced Geothermal Systems (EGS) inject water into engineered fracture networks in hot but dry rock, removing the water-reservoir requirement. Fervo Energy’s Project Red (Nevada) came online in November 2023, supplying 3.5 MW of 24/7 power to Google data centers—the first commercial EGS plant—and demonstrated drilling-cost reductions of 300% in rate, from ~\$9.5 M to ~\$4.5 M per well [5, 7]. Fervo’s

400 MW Cape Station (Utah) is under construction with a 320 MW power-purchase agreement with Southern California Edison [6], and the company has raised over \$460 M with multi-hundred-MW agreements with Google [6, 7]. The US DOE’s Enhanced Geothermal Shot (2022) targets a 90% cost reduction for EGS, to \$45/MWh by 2035 [9].

Superhot rock is the frontier beyond EGS: higher temperature, greater depth, and the supercritical fluid physics of Section 2. It is not incremental—it changes the power per well by an order of magnitude—but it inherits all of EGS’s subsurface engineering, which is why the two must be developed as one program (Table 1).

4 A Century of Drilling Toward the Heat

Geothermal power is not new, and neither is the ambition to reach hotter depth. The milestones that matter for superhot rock are in Table 2 and Figure 3.

Table 2: Key milestones on the path from hydrothermal to superhot rock.

Year	Event	Significance
1904	Larderello, Italy: first geothermal electricity	Proof that the Earth’s heat can turn a turbine; still operating
1960s	The Geysers, California: first large ~1 GW field	Hydrothermal at industrial scale; geographically locked to steam fields
1970–89	Kola Superdeep Borehole (USSR): 12.3 km	Deepest hole ever drilled; proved mechanical drilling can reach 10+ km, at extreme cost and ~180 °C bottom temperature
1974–95	Fenton Hill Hot Dry Rock (Los Alamos, NM)	First engineered-reservoir (EGS precursor) experiments; flow rates too low to be economic, but the concept was proven
1987–94	Soultz-sous-Forêts (France): EU EGS research site	Multi-well stimulation at ~5 km; produced ~1.5 MWe for years; the reference EGS dataset
2009	IDDP-1 (Iceland): 452 °C steam	First superhot fluid in a well; ~36 MWe estimated from a partial test
2016–17	IDDP-2 (Iceland): 465 °C at 4.5 km	First fully supercritical well; the proof-of-concept for SHR
2023	Fervo Project Red (Nevada): 3.5 MW commercial EGS	First commercial engineered geothermal, with Google PPA; drilling rate +300%
2022–24	DOE Enhanced Geothermal Shot; Fervo Cape Station 400 MW; Quaise \$95 M round	Policy target (\$45/MWh by 2035) and capital for the drilling frontier
2026–30	IDDP-3, Krafla Magma Testbed, first gyrotron field demos	Next probes of the supercritical regime; SHR pilots

The lesson of the history is double-edged. On one hand, every step of the ladder—hydrothermal, hot dry rock, EGS, supercritical—was declared uneconomic at its start, and each was unlocked by the same learning curve: cheaper drilling per meter and higher power per well. The 70-year record of Larderello shows what a *continuous* resource delivers when it is developed seriously [21]; Fenton Hill and Soultz showed that engineered reservoirs *work* but were starved of flow, not of temperature [19, 20]. On the other hand, the gap between proof-of-concept (IDDP-2, 2017) and commercial-scale plants is measured in decades, not years: Soultz needed nearly two decades to reach 1.5 MWe, and Kola showed that a 12 km hole takes fifteen years and extraordinary cost even when the goal is scientific [17, 18]. SHR inherits that timeline risk, and any roadmap must price it in.




Figure 3: A century of milestones (Table 2). Gray: hydrothermal; blue: engineered reservoirs; orange/red: supercritical demonstrations; green: commercial EGS; dark blue: the SHR era.

5 The Drilling Problem

Every honest assessment of SHR converges on the same sentence: the geology is ready; the drilling is not. Conventional rotary drilling—the best-developed technology on Earth—hits three walls at depth:

1. **Temperature:** elastomer seals, electronics, and measurement-while-drilling tools fail above $\sim 250^\circ\text{C}$; at $400^\circ\text{C}+$ even the bit bearings and lubricants degrade rapidly.
2. **Cost per meter:** deep wells cost exponentially more—a 5 km geothermal well $\sim \$5$ – 10 M, a 10–20 km well $\$30$ – 100 M+—because rig time, casing, and failure risk all scale with depth. Fervo’s achievement (a 2–3 $\times$ drilling rate gain, $\$1,000/\text{ft}$ to $\sim \$300/\text{ft}$) shows how much is learnable, but the SHR depth regime remains unexplored territory [7, 8].
3. **Wellbore integrity:** casing, cement, and zonal isolation at $400^\circ\text{C}+$ are unsolved at industrial scale; conventional cements degrade, and differential thermal expansion stresses the casing string.

5.1 What Deep Drilling Already Knows

It is worth calibrating the 5–20 km claim against what has actually been drilled. The deepest hole ever made is the Kola Superdeep Borehole (Russia): 12,262 m, drilled 1970–1989, with a bottom temperature of $\sim 180^\circ\text{C}$ and a final cost that made the exercise unrepeatable without a purpose [17]. The German KTB reached 9,101 m in 1994 at $\sim 280^\circ\text{C}$. In both cases the limiting factor was not rock strength but *temperature and rig time*: conventional bits and muds degrade, and each kilometer deep becomes exponentially more expensive. Two conclusions follow. First, 10+ km is mechanically feasible—the tools exist; the economics do not. Second, SHR is precisely the case that *changes the economics*: a 10–12 km hole in normal crust produces 20–50 MWe instead of the few megawatts Kola’s temperature regime would yield, justifying a cost per meter that deep drilling has never previously justified [17, 4]. The supercritical leap is what turns the world’s most expensive well into a power plant.

5.2 The New Drilling Technologies

Because rock *melts or spalls* rather than cutting, several non-contact drilling concepts bypass the temperature limit of tooling (Table 3):

- **Gyrotron (mm-wave) drilling** (Quaise Energy, MIT lineage): a gyrotron—the microwave source originally developed for fusion plasma heating—directs a millimeter-wave beam down the borehole that melts and vaporizes rock into glass. No downhole tooling touches the rock face; the same beam can be used to case the hole. Quaise has raised $\$95$ M and targets drilling to ~ 20 km with pilots in the late 2020s [10].
- **Plasma and laser spallation:** pulsed energy spalls rock by thermal shock; laboratory and pilot systems exist but remain energy-inefficient per meter.

- **Flame-jet and thermal drilling:** hot combustion jets melt rock (used in the 1960s for taconite); simple, but slow and inefficient.
- **Incremental rotary:** hardened high-temperature bits, air-foam drilling, and mud cooling extend conventional drilling toward 300–350 °C—the near-term bridge, not the endgame.

Table 3: Drilling technologies for superhot depths.

Method	Principle	Max temp.	Depth (demo)	TRL	Status
Rotary (incremental)	Mechanical cutting	~350 °C	3–5 km	7–8	Workhorse
Gyrotron (Quaise)	mm-wave melt/vaporize	>1000 °C	~20 km (target)	3–4	\$95M funded
Plasma / laser	Thermal spallation	Unlimited	0.1–1 km	3–5	Laboratory–pilot
Flame jet	Combustion melt	Unlimited	1–2 km (1960s)	3–4	Historical

The gyrotron path is the one that matches the physics: it removes the temperature limit entirely, converts the drilling problem into an energy-delivery and materials problem, and—critically—melts the borehole wall into a glass casing, potentially solving wellbore integrity at the same stroke [10]. Its risks are real (beam delivery at 20 km, hole stability in the melt zone, cost per meter at scale) and are addressed in Section 14.

6 Subsurface Engineering

Even with a perfect borehole, the reservoir must be engineered:

- **Fracture networks at supercritical conditions:** water injected at ~400 °C into engineered fractures must maintain permeability for decades; thermal drawdown, fracture closure, and silica scaling (which precipitates violently when supercritical fluid cools) are first-order design problems [3, 15].
- **Induced seismicity:** stimulation releases seismic energy; the industry standard is the traffic-light protocol (magnitude thresholds trigger mitigation), and Basel/Pohang events show the consequences of ignoring it. The counter-evidence: Fervo’s Utah operations and the FORGE research site have operated within monitoring limits [5, 9].
- **Water and chemistry:** EGS/SHR consumes water (and the working fluid must be managed for losses); closed-loop designs (Eavor) minimize consumption at the cost of lower heat extraction [16]. Corrosion and scaling management dominates O&M chemistry.
- **Monitoring and modeling:** microseismic arrays, fiber-optic sensing (DAS/DTS), and tracer tests form the standard toolkit; the goal is a closed loop from stimulation to production.

7 The Surface Plant

Superhot fluid at 400–500 °C offers surface options that conventional geothermal does not:

- **Flash and binary cycles:** conventional steam turbines and organic Rankine cycles are mature; at supercritical enthalpies a single well pair can drive a 20–50 MWe turbine.
- **Supercritical CO₂ (sCO₂) cycles:** at 450–550 °C, closed-loop sCO₂ Brayton cycles reach 50–60% conversion efficiency with compact turbomachinery—the same cycle being developed for concentrated solar and nuclear—a natural match for SHR [2].
- **Co-products:** high-temperature heat can serve industrial processes directly (steel, cement, ammonia preheating), produce hydrogen via high-temperature electrolysis, or feed district heating as a low-value topping use.

Table 4 compares the conversion options. The choice is an optimization, not a religious one: flash and ORC are proven and cheap; sCO₂ and supercritical steam extract the enthalpy bonus at higher complexity. A pragmatic first plant would run flash or ORC while piloting sCO₂ on a slipstream.

Table 4: Power conversion options for superhot fluid.

Cycle	Principle	Thermal efficiency	TRL	Notes
Flash steam	Throttle super-heated fluid to steam	15–25%	9	Proven; simple; leaves some enthalpy unused
Binary (ORC)	Heat a low-boiling organic working fluid	10–15%	9	Mature; best below ~200 °C
sCO ₂ Brayton	Closed supercritical CO ₂ loop	50–60%	5–6	Compact turbomachinery; the 2030s choice
Supercritical steam	Steam at >220 bar directly	40–45%	7	Utility-scale; needs dry cooling in arid sites

Baseload operation is the primary value: capacity factors of 90–95% with no fuel and no intermittency, dispatchable on command. Siting adds one real constraint—water. Superhot wells produce mostly steam at the surface, so cooling water demand is an order of magnitude lower than conventional geothermal, but arid regions (Nevada, East Africa, the Middle East) still require dry or hybrid cooling, which slightly raises capital cost and slightly lowers efficiency; the economics of Section 8 assume dry cooling.

8 Quantitative Feasibility Model

We size a **100 MWe superhot plant** using a transparent techno-economic model consistent with the Clean Air Task Force’s superhot rock analysis [2].

8.1 Well Field

At ~30 MWe per superhot well pair (conservative within the 20–50 MWe range of Section 2), a 100 MWe plant needs 4–5 production wells plus injectors, drilled to 6–12 km in a high-gradient region (or 12–20 km in normal crust). Drilling dominates capital cost:

$$C_{\text{wells}} = N_{\text{wells}} \times c_{\text{per-well}}, \quad c_{\text{per-well}} = \$30\text{--}60 \text{ M at } 8\text{--}12 \text{ km} \quad (1)$$

(the \$4.5 M cost of Fervo’s ~2.5 km EGS wells scaled by depth and temperature [fervo2023]). A 5-pair field at an average \$45 M/well implies ~\$450 M for the well field.

8.2 Capital Cost and LCOE

Table 5: Cost model of a 100 MWe superhot plant.

Item	Value	Share
Well field (5 pairs, 8–12 km)	\$400–500 M	55–65%
Surface plant (turbine, sCO ₂ cycle, heat exchangers)	\$150–250 M	25–30%
Stimulation, monitoring, site	\$50–100 M	10–15%
Total capital	\$600–850 M	100%
Capacity	100 MWe	
Capacity factor	90–95%	
Annual output	~0.8 TWh	

The levelized cost follows:

$$\text{LCOE} = \frac{C_{\text{cap}} \cdot \text{CRF} + C_{\text{O\&M}}}{E_{\text{annual}}} \quad (2)$$

With \$700 M capital, CRF = 0.07 (30 years, 6% interest), a 100 MWe nameplate at 92% capacity factor, and O&M at \$15/MWh (the dominant operational cost is well-field maintenance and scaling management):

$$\text{LCOE} = \frac{0.07 \times 700 \times 10^6}{0.92 \times 365 \times 24 \times 100} + 15 \approx 61 \$ \text{ MW}^{-1} \text{ h} + 15 \approx 76 \$ \text{ MW}^{-1} \text{ h} \quad (3)$$

Across the \$600–850 M capital range of Table 5 this gives 66 \$ MW^{−1} h **to** 90 \$ MW^{−1} h—competitive with gas combined cycle including carbon cost (\$60–90/MWh), but not yet transformative. The DOE Enhanced Geothermal Shot trajectory changes the arithmetic: it targets a 90% reduction in the cost of the *well field*, the dominant line item. If drilling learning cuts the well field from \$450 M to ~\$200 M (total capital ~\$450 M), the same equation gives ~54 \$ MW^{−1} h; at the full shot trajectory (well field ~\$100 M, total ~\$350 M) it reaches ~45 \$ MW^{−1} h, matching the shot target and the CatF model’s central estimate—below gas with carbon cost and below nuclear SMR estimates (\$100–150/MWh) [2, 9]. The honest reading: *today’s best estimate is \$66–90/MWh; the competitive case is a learning-curve bet on drilling*, quantified in Section 8.3.

8.3 Sensitivity Analysis

Table 6 shows how the central \$76/MWh result moves with the four largest uncertainties. The dominant lever is well-field cost, which is why the DOE shot targets drilling rather than

turbines; the model is comparatively insensitive to capacity factor because SHR plants are designed for 90–95% availability.

Table 6: LCOE sensitivity for the 100 MWe SHR model (base \$76/MWh).

Variable	Low case	High case	LCOE range (\$/MWh)
Well-field cost (\$450 M)	\$-50%	\$+50%	54 – 97
Total capital (\$700 M)	\$600 M	\$850 M	66 – 90
Capacity factor	90%	95%	74 – 78
Discount rate (CRF)	5% (0.065)	8% (0.089)	72 – 89
O&M cost	\$12/MWh	\$20/MWh	73 – 81

The policy-relevant conclusion is uncomfortable but clear: at current costs SHR is a marginal firm-power option; it becomes a world-scale one only if drilling costs fall by a factor of two to three, which is exactly what the DOE shot, Fervo’s demonstrated learning rate (well cost \$9.5 M to \$4.5 M in one project), and the gyrotron program are pursuing [7, 9, 10].




Figure 4: Levelized cost of electricity for firm power options. Gas CCGT, nuclear SMR, and EGS-2024 are published ranges (midpoints); the SHR model is Eq. 2; the 2035 target is the DOE Enhanced Geothermal Shot. Solar + iron-air is the author’s storage companion model, firm 24/7.

9 The World-Scale Case

- **Baseload everywhere:** superhot rock is not tied to volcanic margins; 4.3 TW from 1% of the US resource alone dwarfs the ~1 TW of US peak demand, and the same logic applies on every continent [1, 11].
- **The complement to storage:** storage (iron-air) bridges days; superhot baseload bridges weeks, seasons, and provides the charging energy and the inertia. Together they form the firm backbone that solar and wind plug into—the architecture analyzed in the author’s companion studies.
- **Industrial heat and hydrogen:** 400–500 °C superhot fluid can preheat steel and cement processes and drive high-temperature electrolysis, attacking the ~50% of final energy that is heat [12].

- **Energy security and geopolitics:** a resource under every country’s feet, produced with oil-and-gas drilling skills that already exist in every industrial nation—including Poland, whose coal-basin workforce and drilling industry are directly transferable.
- **Data centers:** 24/7 firm clean power with no fuel is precisely the product hyper-scalers contract for (Google’s Fervo agreements are the EGS proof; SHR extends the geography) [6].

9.1 How SHR Compares with the Alternatives

Table 7 places SHR against the other firm-power candidates on the axes that actually decide grid investment. No option wins every column; the point is that SHR is the only one that is simultaneously anywhere-scalable, fuel-free, weather-independent, and construction-light—at the price of an unproven drilling technology.

Table 7: Firm clean power options compared.

Criterion	Nuclear (SMR)	Gas CCS	+ H ₂ (green)	Storage-only	SHR
Scalability anywhere	Medium (sitting)	High	High	High	High
Firmness (weeks)	Yes	Yes	Via turbines	No (days)	Yes
Fuel cost	Yes (U)	Yes (gas)	Yes (H ₂)	No	No
LCOE today (\$/MWh)	100–150	60–90	150–250	60–90 (firm stack)	66–90
Build time	10–20 yr	3–5 yr	10–15 yr	2–4 yr	6–10 yr (if drilling works)
Public acceptance	Polarizing	Fossil	Neutral	Neutral	Mostly positive
Key risk	Cost, waste	CO ₂ storage	Efficiency, cost	Duration limit	Drilling

The storage-only column deserves a note: with enough iron–air inventory a grid can cross weeks of lull, but the storage volume needed grows linearly with the lull length, so the cost curve is steep; SHR supplies the *energy* side that storage cannot cheaply store. The two are complements, as the author’s companion study on iron–air storage argues in detail.

9.2 Regional Case Studies

Iceland: the living laboratory. IDDP-1 and IDDP-2 proved supercritical fluids exist at accessible depth; IDDP-3 and the Krafla Magma Testbed—which will drill directly into a magma body at ~2 km—are probing the next phase; geothermal already supplies ~70% of Icelandic primary energy [3, 22].

United States: Fervo’s Nevada and Utah projects are commercial EGS; the Utah FORGE research site and DOE’s \$74 M EGS funding round (2024) underpin the shot target; Quaise and others pursue the SHR step [5, 9, 10].

East Africa: the rift valley’s high gradients put supercritical conditions within 3–5 km—potentially transforming a region that currently builds its grid on imported diesel [12].

Poland: the Polish grid, still ~60–70% coal, needs firm clean capacity as coal retires; Polish oil-and-gas drilling experience, coal-basin workforce, and moderate crustal gradients make EGS the near-term entry and SHR the long-term baseload answer—a domestic, non-imported, dispatchable resource beneath the country.

10 Technology Roadmap

Table 8: Technology roadmap for superhot rock geothermal.

Phase	Milestone	Significance
2024–2028	EGS at scale (Fervo Cape 400 MW); FORGE/IDDP-3 supercritical wells; gyrotron drilling demos	EGS economics proven; SHR fluid accessed at test scale
2028–2033	First SHR pilot plants (Iceland, US); gyrotron wells to 6–10 km; sCO ₂ cycle integration	First superhot megawatts; drilling cost learning begins
2033–2040	Commercial SHR plants (100–500 MW); <\$60/MWh demonstrated; industrial-heat co-production	SHR becomes a standard firm-power option, competitive with gas
2040–2050	Terawatt-scale build-out; drilling to 15–20 km in normal crust; hydrogen co-production	Baseload gap closed; storage + SHR the reference grid architecture

Figure 5 renders the phases on a timeline.




Figure 5: Timeline of the roadmap phases of Table 8.

11 Regulation, Permitting, and Social License

SHR is a subsurface, multi-decade, capital-intensive infrastructure business, so its non-technical constraints are as real as its technical ones:

- **Subsurface rights.** Geothermal heat is a mineral-type right in most jurisdictions (US federal leasing under BLM; Poland’s geological law); surface ownership does not imply subsurface rights, and SHR’s 10–20 km reach crosses multiple legal strata and, potentially, jurisdictions.
- **Permitting timelines.** A US geothermal project typically spends 7–10 years from lease to operation (leasing, NEPA review, drilling permits, interconnection); the DOE’s “Categorical Exclusion” push and state-level geothermal bills (e.g., Colorado, Utah) aim

to cut this in half. For a technology whose competitive window is the 2030s, permitting reform is as important as drilling R&D [9].

- **Seismicity regulation.** The traffic-light protocol is becoming law-like: Basel and Pohang ended their projects after felt events, while Fervo’s operations in Utah ran inside monitoring limits. The regulatory pattern that works is transparent siting, baseline monitoring, and pre-agreed magnitude thresholds—not bans [9].
- **Social license.** Geothermal is generally popular (it is local, visible, and creates drilling jobs), unlike nuclear or CO₂ storage; the 2020s “geothermal for data centers” narrative has made it positively fashionable. The risk is localized (an induced event near a town), so early, honest community engagement is the cheapest insurance.

12 Environmental Footprint and Life-Cycle

- **Land use.** ~10 ha per 100 MW (well pads plus plant) versus ~300–800 ha for equivalent solar or wind; footprint per MWh is among the lowest of any electricity source.
- **Emissions.** Geothermal emits trace gases (CO₂, H₂S) from the reservoir itself—typically 50–150 g CO₂/kWh for hydrothermal fields, but ~10–40 g/kWh for closed-loop and deep designs where the fluid is re-injected; SHR’s mostly-steam production and full re-injection keep emissions near the bottom of the table [12].
- **Water.** SHR uses water as a working fluid but consumes little: a closed or semi-closed loop re-injects the brine, and surface cooling (dry towers) removes the largest demand; net consumption is comparable to gas CCGT and far below nuclear once cooling is included.
- **Seismicity and induced effects.** The real environmental risk is induced seismicity (Section 11); monitoring, traffic lights, and conservative stimulation volumes manage it, but it cannot be eliminated, only bounded.
- **Life-cycle and end-of-life.** No fuel, no waste stream, no decommissioning liability beyond plugging wells (standard oil-and-gas practice); the embodied energy of drilling is repaid in months of operation. A 100 MW plant avoids ~0.4 Mt CO₂/yr versus gas—and, unlike solar, at a 90%+ capacity factor, so the *per-MWh* footprint advantage compounds.

13 Myths, Debunked

Because SHR sounds like science fiction, it attracts confident misunderstandings, including from people who should know better:

1. **“Geothermal only works in Iceland.”** False. Conventional *hydrothermal* works only where nature supplied water; *superhot rock* is a function of depth and gradient and exists under nearly every square kilometer of every continent. Iceland matters because it proves the physics at 4.5 km, not because it bounds the resource.
2. **“Drilling 20 km is impossible.”** False. Kola drilled 12.3 km with 1970s technology; the question is cost per meter, which is exactly what gyrotron drilling and learning curves attack. No physical limit is being approached at 20 km.

3. **“It will cause earthquakes everywhere.”** The stimulation-induced events that ended Basel and Pohang were real failures of protocol, not proof of inevitability; thousands of EGS and oil/gas stimulations run inside magnitude limits every year, and the traffic-light protocol exists precisely to keep SHR in that regime [9].
4. **“The water requirement kills it.”** SHR’s working fluid is re-injected in a loop; net consumption is small and dry cooling removes the surface demand. The water concern belongs to the 1970s hot-dry-rock experiments, not to modern closed-loop designs.
5. **“It’s just expensive hot dry rock, which already failed.”** Fenton Hill (1970s) failed on *flow rate*, not temperature; the supercritical leap multiplies power per well by an order of magnitude, which is precisely what the economics of Fenton Hill lacked. Hot dry rock failed at 5 MW/well economics; SHR is a different business at 20–50 MW/well.

14 Risks and Honest Assessment

The concept is promising; it is not proven. The honest list:

1. **Drilling cost at 20 km is unknown.** The \$30–60 M/well assumption is an extrapolation; the true figure could be 2–3× higher, which would push LCOE to \$70–90/MWh—still competitive with gas, but not transformative. Gyrotron drilling has never drilled a 10 km hole; beam delivery, hole stability, and melt-zone casing are unproven at scale [10, 15].
2. **Reservoir performance is unproven.** Supercritical fracture networks may underperform: thermal drawdown, silica scaling, and permeability loss could cut the 90–95% capacity factor and the 30-year life. The only way to know is to drill.
3. **Induced seismicity.** Stimulation risk is real and socially explosive; Basel (M3.4) and Pohang (M5.5) are the cautionary tales. Rigorous traffic-light protocols and transparent siting are non-negotiable [9].
4. **Water and chemistry.** Supercritical fluid handling, corrosion, and scaling dominate O&M; closed-loop designs trade water for performance. Resource characterization (permeability at depth) remains sparse [3, 1].
5. **Timeline risk.** SHR is a 2030s technology: a 10-year slippage on either drilling or reservoirs pushes first commercial plants past 2040, which is a policy and investment-planning risk for grids that must retire coal in the 2030s.
6. **Competition.** Nuclear SMRs, long-duration storage, and gas-with-capture are also pursuing the firm-power role; SHR must win on delivered LCOE and bankability, not on physics elegance.

15 The Case in One Table

Table 9 compresses the entire argument: the pain, the physics, the numbers, the condition, and the verdict.

Table 9: Superhot rock geothermal: the complete case.

Question	Answer	Evidence
What pain?	Firm baseload for weeks-long lulls, industrial heat, energy security	50–100% of peak demand needs firm capacity (Sec. 1)
What physics?	Supercritical water at 374 °C+ carries 3–5× enthalpy and yields ~10× power per well	Steam tables; IDDP-1/2 (Sec. 2)
What resource?	Effectively unlimited: 1% of US SHR = 4.3 TW; exists under every continent	CatF heat mapping (Sec. 2)
What blocks it?	Drilling cost at 5–20 km, 400 °C+	Kola 12.3 km proves feasibility; cost is the issue (Sec. 5)
What’s the answer?	Gyrotron mm-wave drilling; learning curves	Quaise; Fervo 2–3× rate gain (Sec. 5)
What does it cost?	\$66–90/MWh today; ~\$45/MWh at DOE Shot trajectory	Eq. 2, Sec. 8.3
What could kill it?	Drilling cost miss, reservoir underperformance, seismicity, timeline slip	Sec. 14
What’s the role?	Firm backbone complementing iron–air storage; industrial heat	Sec. 9

16 Conclusions

1. **Superhot rock is the only clean firm-power source that scales anywhere.** Its resource is effectively unlimited (1% of the US resource is 4.3 TW), it is independent of weather, and it runs at 90–95% capacity factor with no fuel and a ~10-ha footprint per 100 MW.
2. **The physics is the good news.** Supercritical water at 374 °C+ carries 3–5× the enthalpy per kilogram and yields an order of magnitude more power per well—the one lever that makes deep drilling economic.
3. **The engineering is the honest bottleneck.** Drilling at 5–20 km in 400 °C+ rock is the single unproven element—but 12 km has been drilled before (Kola), so the question is cost per meter, not feasibility. The gyrotron path (Quaise) is the most promising answer and is appropriately the focus of venture and DOE funding [10, 9, 17].
4. **The economics close—on a condition.** A transparent 100 MWe model gives LCOE of \$66–90/MWh at today’s drilling costs (competitive with gas with carbon cost), falling to ~\$45/MWh if the DOE Shot’s drilling-cost reductions are delivered. The shot is therefore not a marketing label; it is the make-or-break assumption of the entire case, and it is the reason the paper’s headline is “drilling, not geology.”
5. **It complements, not competes with, storage.** Iron–air and the storage family bridge days; superhot baseload bridges weeks, seasons, and provides charging energy

and inertia. The author’s three companion studies—betavoltaics, iron–air storage, and this work—form a consistent answer to the energy transition: micro-power where autonomy matters, multi-day storage for the lull, and superhot rock for the backbone.

The energy transition has spent two decades making clean energy cheap and intermittent. The next two decades are about making it firm. The sun shines on the surface by day; the Earth’s heat—the same heat that made the sun-sized energy of the planet’s formation—is available everywhere, at a price set only by our ability to drill. Superhot rock geothermal is not a metaphor for that heat. It is the engineering program that extracts it.

Glossary of Acronyms

BLM US Bureau of Land Management (federal subsurface leasing)

CCGT combined-cycle gas turbine

CF capacity factor

CRF capital-recovery factor

DAS/DTS distributed acoustic / temperature sensing

EGS enhanced geothermal system

FORGE Frontier Observatory for Research in Geothermal Energy

IDDP Iceland Deep Drilling Project

KMT Krafla Magma Testbed

LCOE levelized cost of electricity

MW(e) megawatt (electric)

NEPA US National Environmental Policy Act (permitting review)

O&M operations and maintenance

ORC organic Rankine cycle

PPA power-purchase agreement

sCO₂ supercritical carbon dioxide

SHR superhot rock

SMR small modular reactor

TRL technology readiness level

Acknowledgements

The author thanks the Clean Air Task Force, the Iceland Deep Drilling Project, the US DOE Geothermal Technologies Office, Fervo Energy, and Quaise Energy for publicly accessible data and technical reports. No external funding was received for this work.

References

- [1] Clean Air Task Force, “Superhot rock energy in the U.S.: 1% of the resource could provide 4.3 TW of capacity.” Available: <https://www.catf.us/superhot-rock/heat-mapping/us/>
- [2] Clean Air Task Force, “A preliminary techno-economic model of superhot rock energy,” technical report (2024). Available: <https://www.catf.us/resource/preliminary-techno-economic-model-superhot-rock-energy/>
- [3] Iceland Deep Drilling Project, project documentation: IDDP-1 (452 °C, 2009), IDDP-2 (465 °C at 4.5 km, 2016–17), IDDP-3 (enthalpy target $\geq 3,000$ kJ/kg). Available: <https://iddp.is>
- [4] W. A. Elders, G. O. Friðleifsson, and A. Albertsson, “Drilling to supercritical and superhot conditions in Iceland: improving geothermal economics by utilizing supercritical systems,” *GRC Trans.* **38**, 275 (2014); see also “supercritical wells can produce up to ten times more power than normal high-temperature wells.”
- [5] Fervo Energy, “Technology breakthrough in next-generation geothermal,” July 2023 (Project Red, Nevada: 3.5 MW commercial EGS online). Available: <https://fervoenergy.com>
- [6] Fervo Energy, “320 MW power purchase agreements with Southern California Edison” (Cape Station, Utah, 400 MW project), June 2024. Available: <https://fervoenergy.com>
- [7] ScottMadden, “Energy Industry Update: geothermal,” 2024 (Fervo drilling rate +300%; well cost \$9.5 M to \$4.5 M).
- [8] Public Enterprise, “The Firm Frontier,” 2024 (EGS well costs from $\sim$ \$1,000/ft to $<$ \$300/ft).
- [9] US Department of Energy, “Enhanced Geothermal Shot,” September 2022 (90% cost reduction to \$45/MWh by 2035); Geothermal Technologies Office funding rounds (2023–2024). Available: <https://www.energy.gov/eere/geothermal/enhanced-geothermal-shot>
- [10] IEEE Spectrum, “Fusion tech finds a geothermal application: gyrotron drilling,” March 2024 (\$95 M raised; drilling to $\sim$ 20 km). Available: <https://spectrum.ieee.org/geothermal-energy-gyrotron-quaise>
- [11] Cornell University News, “Superhot rock energy could power geothermal systems anywhere,” December 2024.
- [12] Carnegie Endowment for International Peace, “Clean energy dominance through partnership: an international geothermal agenda,” July 2025.
- [13] US DOE, “GeoVision: harnessing the heat beneath our feet,” 2019 (conventional geothermal $\sim$ 60 GW US potential by 2050; global hydrothermal context). Available: <https://www.energy.gov/eere/geothermal/geovision>
- [14] International Energy Agency, “World Energy Outlook 2024,” IEA, Paris (2024) (firm-capacity requirements in net-zero scenarios).

- [15] University of Houston, “Advances in geothermal: white paper,” February 2026 (LCOE as the central challenge for advanced geothermal).
- [16] Eavor Technologies, closed-loop geothermal documentation, 2020–2026. Available: <https://www.eavor.com>
- [17] Kola Superdeep Borehole (SG-3), project documentation, 1970–1994 (final depth 12,262 m; bottom temperature $\sim 180^\circ\text{C}$). Available: https://en.wikipedia.org/wiki/Kola_Superdeep_Borehole
- [18] Kontinentales Tiefbohrprogramm (KTB), Germany: 9,101 m pilot and main holes, drilled 1987–1994 (bottom temperature $\sim 280^\circ\text{C}$). Available: <https://www.gfz-potsdam.de/en/ktb>
- [19] Los Alamos National Laboratory, Fenton Hill Hot Dry Rock project, 1974–1995: first engineered geothermal reservoir experiments at $\sim 3\text{--}4$ km and $180\text{--}330^\circ\text{C}$. Available: <https://www.energy.gov/eere/geothermal/hot-dry-rock>
- [20] European Hot Dry Rock program, Soultz-sous-Forêts, France: multi-well EGS research at ~ 5 km, $\sim 200^\circ\text{C}$, producing ~ 1.5 MWe (1990s–2008). Available: <https://www.geothermie-soultz.fr>
- [21] Enel Green Power, Larderello geothermal field, Tuscany, Italy: first geothermal electricity (1904), ~ 800 MWe installed today. Available: <https://www.enelgreenpower.com/geothermal>
- [22] Krafla Magma Testbed (KMT), Iceland: planned drilling into the Krafla magma chamber at ~ 2.1 km (2026–2028), following the IDDP-1 magma encounter (2009). Available: <https://www.kmt.is>