





	1	2	3	4	5	6
	Total inlet water	Total raw water	Raw water to water purification	Total purified water	Pure water to desalination	Total desalinated water
Flow, m3/h	6589,30	3825,00	2764,30	2644,30	120,00	83,10
Purification			2764,30	2644,30		
Desalination					120,00	
Sinter						
Blast Furnace						
Process						
Converter						
Casting						
HSM						
CRM						
Galva						
Air plant						
Hydrogen						
Detox						
Filtration						
Raw water use cooling once thru, m3/h	3104,00					
Pure water use cooling once thru, m3/h	1471,00					


Process	Flow in	Flow out	Leakage
	Flow, m3/h		
Purification	2764,30	2764,30	0,00
Desalination	120,00	201,60	-81,60
Sinter	197,00	194,00	3,00
Blast Furnace	3751,40	3566,00	185,40
Process	379,00	379,00	0,00
Converter	433,00	350,00	83,00
Casting	239,00	180,00	59,00
HSM	217,60	147,00	70,60
CRM	1044,20	1043,00	1,20
Galva	11,90	11,00	0,90
Air plant	440,00	440,00	0,00
Hydrogen	19,30	0,00	19,30
Detox	0,00	36,00	-36,00

Filtration	287,00	287,00	0,00
Total	9903,70	9598,90	304,80




[illegible]



Facility Block Flow Diagram - Case Study Bremen



[illegible]



[illegible]



[illegible]

