

**EXTERNAL ELECTRICAL WORKS FOR BUKIT NANAS, AMPANG INTAKE, CHERAS MILE 11 AND  
SG SERAI WTPs**

**SCHEDULE OF PARTICULAR D - SG. SERAI WTP**

<b>Item No.</b>	<b>Description</b>	<b>Tender Specification</b>	<b>Tenderer's Particular</b>
<b>3</b>	<b>Earthing System</b>	SAGA, SAG, Pekat, Tokai, Furse, Duval, Marsa or equivalent	
<b>A</b>	<b>Copper Tape</b> Manufacturer Country of Manufacture Type/Model Standard To Which Manufactured Material / Finish Size	To Offer To Offer To Offer MS IEC 62305 Copper 25mm x 3mm	
<b>B</b>	<b>Earth Rod</b> Manufacturer Country of Manufacture Type/Model Material / Finish Standard To Which Manufactured	To Offer To Offer To Offer Copperbond MS IEC 62305	
<b>C</b>	<b>Earth Pit/Chamber</b> Manufacturer Country of Manufacture Type/Model Standard To Which Manufactured	To Offer To Offer Heavy Duty Concrete MS IEC 62305	
<b>D</b>	<b>Exothermic Welding</b> Manufacturer Country of Manufacture Model No. Standard/Technical Specification	To Offer To Offer To Offer MS IEC 62305	

**Note:**

- (i) To attach catalogue with SPAN/ SIRIM/ IKRAM certification, if available.
- (ii) All warranties shall commence from the date of CPC and shall not less than DLP.

.....  
Signature and Official  
Stamp of Tenderer

Date : .....