

**EXTERNAL ELECTRICAL WORKS FOR BUKIT NANAS, AMPANG INTAKE, CHERAS MILE 11 AND  
SG SERAI WTPs**

**SCHEDULE OF PARTICULAR C - CHERAS MILE 11 WTP**

<b>Item No.</b>	<b>Description</b>	<b>Tender Specification</b>	<b>Tenderer's Particular</b>
<b>2</b>	<b>CABLE</b>	Mega Cable, Central Cable, Olympic Cable, Southern Cable or equivalent	
<b>A</b>	<b>XLPE/SWA/PVC Cable</b> Manufacturer Voltage Rating Standard To Which Manufactured	To Offer 1000/600V IEC 60502	
<b>B</b>	<b>PVC/SWA/PVC Cable</b> Manufacturer Voltage Rating Standard To Which Manufactured	To Offer 1000/600V IEC 60502	
<b>C</b>	<b>PVC Insulated Cable</b> Manufacturer Voltage Rating Standard To Which Manufactured	To Offer 1000/600V IEC 60502	
<b>D</b>	<b>PVC/PVC Control Cable</b> Manufacturer Voltage Rating Standard To Which Manufactured	To Offer 1000/600V IEC 60502	
<b>E</b>	<b>Overhead Cable</b> Manufacturer Voltage Rating Standard To Which Manufactured	To Offer 1000/600V IEC 60502	

**Note:**

- (i) To attach catalogue with SPAN/ SIRIM/ IKRAM certification, if available.
- (ii) All warranties shall commence from the date of CPC and shall not less than DLP.

.....  
Signature and Official  
Stamp of Tenderer

Date : .....