

**EXTERNAL ELECTRICAL WORKS FOR BUKIT NANAS, AMPANG INTAKE, CHERAS MILE 11 AND
SG SERAI WTPs**

SCHEDULE OF PARTICULAR B - AMPANG INTAKE WTP

Item No.	Description	Tender Specification	Tenderer's Particular
2	CABLE	Mega Cable, Central Cable, Olympic Cable, Southern Cable or equivalent	
A	XLPE/SWA/PVC Cable Manufacturer Voltage Rating Standard To Which Manufactured	To Offer 1000/600V IEC 60502	
B	PVC/SWA/PVC Cable Manufacturer Voltage Rating Standard To Which Manufactured	To Offer 1000/600V IEC 60502	
C	PVC Insulated Cable Manufacturer Voltage Rating Standard To Which Manufactured	To Offer 1000/600V IEC 60502	
D	PVC/PVC Control Cable Manufacturer Voltage Rating Standard To Which Manufactured	To Offer 1000/600V IEC 60502	
E	Overhead Cable Manufacturer Voltage Rating Standard To Which Manufactured	To Offer 1000/600V IEC 60502	

Note:

- (i) To attach catalogue with SPAN/ SIRIM/ IKRAM certification, if available.
- (ii) All warranties shall commence from the date of CPC and shall not less than DLP.

.....
Signature and Official
Stamp of Tenderer

Date :