

Custom Procurement Report

Control How You Source Building Systems

Directly access suppliers and automate sourcing, procurement, and financing—all from one platform



Customer Information

Customer Villanova University

Name Contact Not Specified

Person Contact N/A **Email** Contact N/A **Phone**

Architect Blackney Hayes Architects Engineer Of PSquared Consulting Engineers Record

Contractor Not Specified

Project Information

Project Villanova University - Founders Hall HVAC Renovation

Name Location Founders Hall, 610 King of Prussia Road, Wayne, PA 19087

Start Date N/A Completion N/A **Date Budget** N/A

Scope HVAC system installation/renovation including makeup air units,

water-source heat pumps, cooling tower, dedicated outdoor air sys-

tem, and variable refrigerant flow system

Project ID Founders Hall HVAC System

Project URL N/A

Design Issued for Bid Stage Design May 5, 2025

Date

Prepared By

Ben Lyddane Ben@BuildVision.io 202-365-8628

Mackenzie Hoover Mackenzie@buildvision.io 843-609-3265

Date: 2025-05-20

Project Equipment

Packaged, Outdoor, Heating-Only Makeup-Air Units

| Equipment Tag | Manufacturer | Model |
|----------------------|--------------|-------------|
| MUA-1 | CaptiveAire | A2D-250-20B |
| MUA-2 | CaptiveAire | A2D-250-20B |
| MUA-3 | CaptiveAire | A2D-250-20B |

Notes

Low lead time (<10 weeks), specification section 23 73 23

Automatic Condensate Pump Units

| Equipment Tag | Manufacturer | Model | |
|----------------------|-------------------------|-----------------|--|
| CP-239 | Blue Diamond Pumps Inc. | X87-721 MANULUC | |

Notes

Low lead time (<10 weeks), specification section 23 05 33

HVAC Fans

| Equipment Tag | Manufacturer | Model |
|----------------------|--------------|-----------|
| EF-1 | CaptiveAire | USDH-RM |
| EF-2 | CaptiveAire | USDH-RM |
| EF-3 | CaptiveAire | DLX260-TA |
| EF-5 | PennBarry | DX-38 |

Notes

Low lead time (<10 weeks), specification section 23 34 23

In-Line Centrifugal Hydronic Pumps

| Equipment Tag | Manufacturer | Model |
|----------------------|----------------|-------|
| P-3A | Bell & Gossett | E-80 |
| P-3B | Bell & Gossett | E-80 |

Notes

Medium lead time (10-20 weeks), specification section 23 21 23

Base-Mounted, Centrifugal Hydronic Pumps

| Equipment Tag | Manufacturer | Model |
|----------------------|----------------|--------|
| P-6A | Bell & Gossett | E-1510 |
| P-6B | Bell & Gossett | E-1510 |

Notes

Medium lead time (10-20 weeks), specification section 23 21 23

Water-Source Heat Pumps

| Equipment Tag | Manufacturer | Model |
|----------------------|--------------|---------|
| WSHP-1 | Trane | EXRK009 |
| WSHP-2 | Trane | EXRK012 |
| WSHP-3 | Trane | EXRK012 |
| WSHP-4 | Trane | EXRK020 |
| WSHP-5 | Trane | EXRK030 |
| WSHP-6 | Trane | EXRK035 |
| WSHP-7 | Trane | EXRK042 |
| WSHP-8 | Trane | EXRK042 |
| WSHP-9 | Trane | EXRK055 |

Notes

Medium lead time (10-20 weeks), specification section 23 81 29, prefabrication coordination advised

Closed-Circuit, Forced-Draft Cooling Towers

| Equipment Tag | Manufacturer | Model |
|----------------------|--------------|------------|
| CT-1 | EVAPCO | ATWB 7-7-9 |

Notes

High lead time (>20 weeks), specification section 23 65 33, high-cost driver, ensure early release

Radiators

| Equipment Tag | Manufacturer | Model |
|----------------------|---------------|------------------|
| CUH-1 | Sterling HVAC | MODEL RW SIZE 02 |
| CUH-2 | Sterling HVAC | MODEL F SIZE 02 |

Notes

Low lead time (<10 weeks), specification section 23 83 19

Dedicated Outdoor-Air Units

| Equipment Tag | Manufacturer | Model |
|----------------------|--------------|---------------------|
| DOAS-1 | Trane | OADG030C3-DAB1GB600 |

Notes

Medium lead time (10-20 weeks), specification section 23 73 13, high-cost driver, ensure early release

Packaged Rooftop Air-Conditioning Units

| Equipment Tag | Manufacturer | Model |
|----------------------|--------------|-----------|
| RTU-4 | Trane | YCH420D4P |

Notes

Medium lead time (10-20 weeks), specification section 23 74 13

Variable Refrigerant Flow Systems

| Equipment Tag | Manufacturer | Model | |
|----------------------|--|------------|--|
| AC-239 | Mitsubishi Electric (Including Trane Products) | PKA-AK24NL | |
| CU-239 | Mitsubishi Electric (Including Trane Products) | PUY-AH24NL | |

Notes

High lead time (>20 weeks), specification section 23 81 26, verify controls integration

Suppliers

Packaged, Outdoor, Heating-Only Makeup-Air Units

Note: Cost differences are Al-estimated percentages relative to Basis of Design and are not based on actual project data. Always obtain accurate quotes from vendors directly via buildvision.io.

| Manufacturer | Model | Representativ | Al Est. Cost D | Compatibility Notes | BoD |
|--------------|----------------------|----------------------------------|----------------|--|-----|
| CaptiveAire | A2D Series | N/A | | Basis of Design | Yes |
| Greenheck | MSX Series | Greenheck Representa- tive | +5-10% | Compatible alternative, verify footprint and gas connection locations | No |
| Modine | Hot Dawg Se- ries | Modine Representative | -3-5% | May require modifications to ductwork connections and controls interface | No |

Automatic Condensate Pump Units

Note: Cost differences are Al-estimated percentages relative to Basis of Design and are not based on actual project data. Always obtain accurate quotes from vendors directly via buildvision.io.

| Manufacturer | Model | Representativ | Al Est. Cost D | Compatibility Notes | BoD |
|--------------|---|-------------------------------------|----------------|--|-----|
| Blue | Diamond Pumps Inc. X87-721 MANULUC | N/A | | Basis of Design | Yes |
| Little Giant | VCMA Series | Little Giant Representa- tive | -5-10% | Widely available alterna- tive, verify power require- ments and capacity | No |

HVAC Fans

Note: Cost differences are Al-estimated percentages relative to Basis of Design and are not based on actual project data. Always obtain accurate quotes from vendors directly via buildvision.io.

| Manufacturer | Model | Representativ | Al Est. Cost D | Compatibility Notes | BoD |
|--------------|---------------------------|----------------------------------|----------------|---|-----|
| CaptiveAire | USDH- RM/DLX Series | N/A | | Basis of Design | Yes |
| Greenheck | SQ/SP Series | Greenheck Representa- tive | +2-8% | Compatible alternative, verify dimensions and electrical requirements | No |

Hydronic Pumps

Note: Cost differences are Al-estimated percentages relative to Basis of Design and are not based on actual project data. Always obtain accurate quotes from vendors directly via buildvision.io.

| Manufacturer | Model | Representativ | Al Est. Cost D | Compatibility Notes | BoD |
|--------------|------------------------------------|---------------------------------|----------------|--|-----|
| Bell | & Gossett E-80/E-1510 Series | N/A | | Basis of Design | Yes |
| Taco | FI/KS Series | Taco Representative | -2-5% | Compatible alternative, confirm pump curves and electrical characteristics | No |
| Grundfos | TP/HS Series | Grundfos Representa- tive | +5-10% | Premium efficiency models available, confirm flange dimensions and compatibility | No |

Water-Source Heat Pumps

Note: Cost differences are Al-estimated percentages relative to Basis of Design and are not based on actual project data. Always obtain accurate quotes from vendors directly via buildvision.io.

| Manufacturer | Model | Representativ | Al Est. Cost D | Compatibility Notes | BoD |
|---------------|-----------------------|--------------------------------------|----------------|--|-----|
| Trane | EXRK Series | N/A | | Basis of Design | Yes |
| Daikin | SmartSource Series | Daikin Representative | +3-7% | Verify dimensions, connection locations, and control compatibility | No |
| ClimateMaster | Tranquility Series | ClimateMaster Representa- tive | -2-5% | May require different control interface, verify dimensions and connection points | No |

Closed-Circuit, Forced-Draft Cooling Towers

Note: Cost differences are Al-estimated percentages relative to Basis of Design and are not based on actual project data. Always obtain accurate quotes from vendors directly via buildvision.io.

| Manufacturer | Model | Representativ | Al Est. Cost D | Compatibility Notes | BoD |
|--------------|-------------|---------------|----------------|---------------------|-----|
| EVAPCO | ATWB Series | N/A | | Basis of Design | Yes |

| Baltimore | FXV Series | BAC Repre- | +8-12% | Premium alternative, ver- | No |
|---|------------|-----------------------------------|--------|---|----|
| Aircoil Company (BAC) | | sentative | | ify footprint, connection lo- cations, and structural re- | |
| , tarray | | | | quirements | |
| SPX Cooling Technologies (Marley) | NC Series | SPX/Marley Representa- tive | +5-8% | Verify physical dimensions, structural requirements, and water treatment compatibility | No |

Radiators

Note: Cost differences are Al-estimated percentages relative to Basis of Design and are not based on actual project data. Always obtain accurate quotes from vendors directly via buildvision.io.

| Manufacturer | Model | Representativ | Al Est. Cost D | Compatibility Notes | BoD |
|--------------|-------------------------|------------------------------|----------------|---|-----|
| Sterling | HVAC RW/F Series | N/A | | Basis of Design | Yes |
| Rittling | Cabinet Unit Heaters | Rittling Rep- resentative | +3-7% | Compatible alternative, verify dimensions and connection points | No |

Dedicated Outdoor-Air Units and Rooftop Units

Note: Cost differences are Al-estimated percentages relative to Basis of Design and are not based on actual project data. Always obtain accurate quotes from vendors directly via buildvision.io.

| Manufacturer | Model | Representativ | Al Est. Cost D | Compatibility Notes | BoD |
|--------------|-------------------------|-----------------------------|----------------|--|-----|
| Trane | OADG/YCH Series | N/A | | Basis of Design | Yes |
| Daikin | Rebel/Rooftop Series | Daikin Representative | +5-10% | Verify dimensions, weight, connection points, and controls compatibility | No |
| Carrier | 62X/48HC Series | Carrier Rep- resentative | +2-6% | Compatible alternative, verify footprint, connection locations, and controls | No |

Variable Refrigerant Flow Systems

Note: Cost differences are Al-estimated percentages relative to Basis of Design and are not based on actual project data. Always obtain accurate quotes from vendors directly via buildvision.io.

| Manufacturer | Model | Representativ | Al Est. Cost D | Compatibility Notes | BoD |
|----------------|-------------------------------|--------------------------------|----------------|---|-----|
| Mitsubishi | Electric PKA/PUY Series | N/A | | Basis of Design | Yes |
| Daikin | VRV System | Daikin Representative | -3-8% | May require reconfiguration of refrigerant piping and controls | No |
| LG Electronics | Multi V Series | LG HVAC Representa- tive | -5-10% | Verify compatibility with building management sys- tem and refrigerant line sizing | No |

Design Notes

Hydronic System

Technical Observations:

- Cooling tower (CT-1) is high-cost driver; requires early release
- Bell & Gossett pumps include both inline (E-80) and base-mounted (E-1510) types
- Water-source heat pump loop requires careful coordination with piping systems

Concerns:

- Cooling tower specification section not clearly matched in Division 23 table of contents
- · Ensure that seismic and winterization accessories are specified for cooling tower
- Pumps listed include both inline and base-mounted types; ensure specification section 23 21 23 covers both types and installation baseplates

Opportunities:

- Water treatment system coordination can be optimized between cooling tower and heat pump loop
- · Potential for value engineering on pump redundancy configuration
- Consider variable flow pumping strategies for energy savings

Airside System

Technical Observations:

- · DOAS is high-cost driver; requires early release
- System includes a mix of CaptiveAire and PennBarry fans
- DOAS and RTU both from Trane potential for package discount

Concerns:

- Check redundancy in air handling, particularly with energy recovery provisions between DOAS and RTU
- Multiple fan manufacturers may complicate maintenance and parts inventory
- · Verify control system coordination between all airside components

Opportunities:

- Standardize on single fan manufacturer where possible
- Consider energy recovery options between exhaust fans and makeup air units
- Prefabrication potential for ductwork systems to reduce field labor

DX System

Technical Observations:

- VRF system uses Mitsubishi products that include Trane integration
- System includes both water-source heat pumps and VRF technology

Concerns:

- Lead times for Mitsubishi and Trane VRF components can be long—high risk
- Specification 23 81 26 (VRF) covers Mitsubishi but spec basis-of-design form not located
- Control system coordination with Trane VRF and BMS not explicitly cross-referenced; high risk for submittal delay or integration gaps
- · Confirm warranty path and controls compatibility

Opportunities:

- Early pre-purchase of VRF equipment to mitigate lead time risks
- Coordinate controls integration during early submittal phase
- Consider commissioning agent involvement during controls integration

BuildVision Recommendations

1. Early procurement of high-risk, long lead-time items

Rationale: Cooling tower (EVAPCO ATWB), DOAS (Trane), and VRF components (Mitsubishi) all have lead times exceeding 20 weeks and are critical to the project schedule. **Estimated Impact:** Reduction of project schedule risk by 4-6 weeks, avoiding costly temporary solutions

Implementation: Issue early purchase orders for cooling tower, DOAS, and VRF equipment

after expedited submittal review

Priority: High

2. Comprehensive controls coordination meeting

Rationale: Multiple system types (hydronic, airside, VRF) with different manufacturers will require careful integration with the building automation system.

Estimated Impact: Reduction of commissioning duration by 2-3 weeks and minimization of change orders related to controls integration

Implementation: Schedule pre-submittal controls coordination meeting with all equipment vendors, controls contractor, and engineer

Priority: High

3. WSHP prefabrication strategy

Rationale: Nine water-source heat pumps with similar configurations present an opportunity for prefabrication and standardized installation.

Estimated Impact: Labor savings of 15-20% on WSHP installation, improved quality control, and reduced field coordination issues

Implementation: Develop prefabrication drawings for WSHP installations including piping

assemblies, supports, and connection details

Priority: Medium

4. Review and verify specification coverage

Rationale: Several discrepancies noted in specification references, particularly for cooling tower, VRF, and pumps.

Estimated Impact: Elimination of RFIs and potential change orders related to unclear specifications

Implementation: Conduct comprehensive specification review and submit consolidated

RFI for all identified gaps

Priority: Medium

5. Prioritized submittal schedule

Rationale: Complex project with multiple equipment types requires strategic approach to submittal process.

Estimated Impact: Streamlined approval process for critical path items, reducing overall procurement timeline by 2-3 weeks

Implementation: Develop tiered submittal schedule with priority for cooling tower, DOAS,

VRF, and controls integration

Priority: High

6. Alternative VRF manufacturer evaluation

Rationale: Mitsubishi VRF components have long lead times and relatively high cost compared to alternatives.

Estimated Impact: Potential cost savings of 5-10% on VRF components and possible lead time reduction of 2-4 weeks

Implementation: Evaluate Daikin or LG as alternative VRF suppliers, focusing on controls

compatibility and performance specifications

Priority: Medium

Conclusion

Key Findings

- High-risk equipment with extended lead times (cooling tower, DOAS, VRF) requires expedited procurement
- Multiple system types (hydronic, airside, VRF) with different manufacturers present controls integration challenges
- Specifications contain several gaps or discrepancies that should be addressed via RFIs
- Water-source heat pump quantity provides opportunity for prefabrication efficiency
- Alternative manufacturers for VRF components may offer cost and schedule advantages

Highest Priority Actions

- Develop expedited submittal and procurement plan for long-lead equipment (cooling tower, DOAS, VRF)
- Schedule comprehensive controls coordination meeting with all stakeholders
- Submit consolidated RFI addressing specification gaps and discrepancies
- · Evaluate alternative VRF manufacturers for potential cost and schedule benefits
- Develop WSHP prefabrication strategy to improve installation efficiency

Summary

The Villanova University Founders Hall HVAC renovation project presents a complex mix of hydronic, airside, and DX systems that will require careful coordination during procurement, installation, and commissioning. The critical path items, including the cooling tower, DOAS, and VRF components, have significant lead times and should be prioritized for early procurement. Controls integration across multiple system types represents a high-risk area that demands focused attention early in the project lifecycle. Several opportunities exist for cost and schedule optimization, particularly in the areas of prefabrication, alternative manufacturer evaluation, and strategically sequenced submittals.



Ben Lyddane Ben@BuildVision.io 202-365-8628

Mackenzie Hoover Mackenzie@buildvision.io 843-609-3265

Date: 2025-05-20